

ISSN 1088-3800

Assessment of the 1991 NEHRP Provisions for Nonstructural Components and Recommended Revisions

by

T.T. Soong, G. Chen, Z. Wu, R-H. Zhang and M. Grigoriu

Technical Report NCEER-93-0003

March 1, 1993


This research was conducted at the University at Buffalo, State University of New York and Cornell University and was supported in whole or in part by the National Science Foundation under grant number BCS 90-25010 and the New York State Science and Technology Foundation under Grant No. NEC-91029.

NOTICE

This report was prepared by the University at Buffalo, State University of New York and Cornell University as a result of research sponsored by the National Center for Earthquake Engineering Research (NCEER) through a grant from the National Science Foundation, and other sponsors. Neither NCEER, associates of NCEER, its sponsors, the University at Buffalo, State University of New York and Cornell University nor any person acting on their behalf:

- a. makes any warranty, express or implied, with respect to the use of any information, apparatus, method, or process disclosed in this report or that such use may not infringe upon privately owned rights; or
- b. assumes any liabilities of whatsoever kind with respect to the use of, or the damage resulting from the use of, any information, apparatus, method, or process disclosed in this report.

Any opinions, findings, and conclusions or recommendations expressed in this publication are those of the author(s) and do not necessarily reflect the views of NCEER, the National Science Foundation, or other sponsors.



**Assessment of the 1991 NEHRP Provisions
for Nonstructural Components and Recommended Revisions**

by

T.T. Soong¹, G. Chen², Z. Wu³, R-H. Zhang² and M. Grigoriu⁴

March 1, 1993

Technical Report NCEER-93-0003

NCEER Project Numbers 91-5221 and 92-3201

NSF Master Contract Number BCS 90-25010

and

NYSSTF Grant Number NEC-91029


- 1 Samuel P. Capen Professor, Department of Civil Engineering, State University of New York at Buffalo
- 2 Research Associate, Department of Civil Engineering, State University of New York at Buffalo
- 3 Visiting Assistant Professor, Department of Civil Engineering, State University of New York at Buffalo (from Dalian University of Technology, Dalian, China)
- 4 Professor, School of Civil and Environmental Engineering, Cornell University

NATIONAL CENTER FOR EARTHQUAKE ENGINEERING RESEARCH
State University of New York at Buffalo
Red Jacket Quadrangle, Buffalo, NY 14261

PREFACE

The National Center for Earthquake Engineering Research (NCEER) was established to expand and disseminate knowledge about earthquakes, improve earthquake-resistant design, and implement seismic hazard mitigation procedures to minimize loss of lives and property. The emphasis is on structures in the eastern and central United States and lifelines throughout the country that are found in zones of low, moderate, and high seismicity.

NCEER's research and implementation plan in years six through ten (1991-1996) comprises four interlocked elements, as shown in the figure below. Element I, Basic Research, is carried out to support projects in the Applied Research area. Element II, Applied Research, is the major focus of work for years six through ten. Element III, Demonstration Projects, have been planned to support Applied Research projects, and will be either case studies or regional studies. Element IV, Implementation, will result from activity in the four Applied Research projects, and from Demonstration Projects.



Research tasks in the **Nonstructural Components Project** focus on analytical and experimental investigations of seismic behavior of secondary systems, investigating hazard mitigation through optimization and protection, and developing rational criteria and procedures for seismic design and performance evaluation. Specifically, tasks are being performed to: (1) provide a risk analysis of a selected group of nonstructural elements; (2) improve simplified analysis so that research results can be readily used by practicing engineers; (3) protect sensitive equipment and critical subsystems using passive, active or hybrid systems; and (4) develop design and performance evaluation guidelines.

The end product of the **Nonstructural Components Project** will be a set of simple guidelines for design, performance evaluation, support design, and protection and mitigation measures in the form of handbooks or computer codes, and software and hardware associated with innovative protection technology.

The work presented in this report represents one part of the 1994 update effort of the 1991 NEHRP provisions. The seismic design formulas for nonstructural components as they exist in 1991 NEHRP are critically reviewed and various levels of improvements to these formulas are recommended based on analyses and experiments, performed by NCEER researchers and elsewhere, as well as on observation data from past earthquakes. The recommended revisions thus bring the existing formulas more in line with the state-of-the-knowledge in the area of seismic behavior of nonstructural components. Also proposed in this report is a set of displacement equations which can be useful in the design process.

ABSTRACT

As one part of the 1994 update effort of the 1991 NEHRP provisions, the seismic design force formulas for nonstructural components as they exist in the 1991 provisions are critically assessed and some of their shortcomings are identified. Various levels of improvements to these formulas are then presented which, on the one hand, preserve the equivalent lateral force format for design applicability and, on the other, correct some of their deficiencies on the basis of analyses, experimental results and observation data from past earthquakes.

Based on different interpretations of the component seismic coefficients as well as different degrees of simplicity required in practical design, three recommendations are proposed. The first recommended revision is the most comprehensive in that both effects of nonstructural component anchorage detailing and its supporting structural characteristics are taken into account. The second recommendation is a structure-driven type of modification of the current provisions and is motivated by the possibility that nonstructural component information during a design process is not available. The third revision, however, mainly concentrates on the effect of nonstructural component characteristics on the design force although it partially implies structural effects in the process of determining the response modification coefficient. The maximum and minimum design forces in the three recommendations are compared with those produced by the 1991 NEHRP provisions, the 1991 UBC, and the 1985 Tri-Service codes. Case studies of a parapet, a storage rack and a general equipment attached to a reinforced concrete shear wall structure are provided to show the relative conservatism involved in different codes and the importance of the factors ignored in the current provisions.

Simple displacement equations are also developed in this report to provide deformation information needed in some cases of practical design.

ACKNOWLEDGEMENTS

This work was supported in part by the National Center for Earthquake Engineering Research under Grant Nos. NCEER-91-5221 and NCEER-92-3201; by the State University of New York at Buffalo; and by the IBM Corporation under the NCEER/IBM Joint Research Program on Seismic Performance and Safety Enhancement of Computer and Data Processing Equipment.

TABLE OF CONTENTS

| | Page |
|--|------|
| 1 INTRODUCTION | 1-1 |
| 2 AN ASSESSMENT OF 1991 NEHRP PROVISIONS | 2-1 |
| 2.1 Brief Summary of the Current Design Forces | 2-1 |
| 2.1.1 Architectural Components | 2-1 |
| 2.1.2 Mechanical and Electrical Components | 2-1 |
| 2.1.3 Comments on the Seismic Coefficient (C_c) | 2-2 |
| 2.2 Shortcomings of Present Provision | 2-3 |
| 2.2.1 Soil Type Effect | 2-3 |
| 2.2.2 Location Effect | 2-4 |
| 2.2.3 Structural Period Effect | 2-4 |
| 2.2.4 Structural Yielding Effect | 2-4 |
| 2.2.5 Anchorage Detailing Effect | 2-5 |
| 3 FIRST RECOMMENDATION | 3-1 |
| 3.1 Suggested Revision of the Design Force | 3-1 |
| 3.1.1 Design Force Equation | 3-1 |
| 3.1.2 Development of the Design Force Equation | 3-2 |
| 3.1.3 Performance Criteria Factor (P) and Response Modification Coefficient (R_c) | 3-5 |
| 3.1.4 Comments on Structural Yielding Effect | 3-6 |
| 3.2 Justifications | 3-6 |
| 3.2.1 Theoretical Analyses | 3-7 |
| 3.2.2 Experimental Results | 3-11 |
| 3.2.3 Observations on Past Earthquakes | 3-13 |
| 3.2.4 Related Design Codes | 3-13 |
| 4 SECOND RECOMMENDATION | 4-1 |
| 5 THIRD RECOMMENDATION | 5-1 |
| 5.1 Suggested Revision of the Design Force | 5-1 |
| 5.1.1 Design Force Equation | 5-1 |
| 5.1.2 Development of the Design Force Equation | 5-2 |
| 5.1.3 Determination of Response Modification Coefficient (R_c) | 5-2 |

| | | |
|-------|---|-----|
| 6 | COMPARISON OF DESIGN FORCES..... | 6-1 |
| 6.1 | Maximum and Minimum Design Forces..... | 6-1 |
| 6.2 | Case Studies (Parapets, Storage Racks, and General Equipment on Reinforced Concrete Shear Walls) | 6-1 |
| 6.2.1 | Effects of Soil Type, Structural Period and Component Location..... | 6-1 |
| 6.2.2 | Comparisons Among the Three Recommendations | 6-2 |
| 6.2.3 | Recommended Revisions vs. U.S. Codes/Provisions | 6-3 |
| 7 | DESIGN DISPLACEMENT | 7-1 |
| 7.1 | Flexible Support Deformation..... | 7-1 |
| 7.1.1 | Displacement Equation | 7-1 |
| 7.1.2 | Example: A General Equipment..... | 7-2 |
| 7.2 | Sliding Displacement | 7-2 |
| 7.2.1 | Displacement Equation | 7-2 |
| 7.2.2 | Development of the Displacement Equation | 7-3 |
| 7.3 | Interstory Distortion | 7-4 |
| 8 | CONCLUDING REMARKS..... | 8-1 |
| 9 | REFERENCES | 9-1 |
| | APPENDIX - OBSERVATION DATA FROM SELECTED PAST EARTHQUAKES ... | A-1 |

LIST OF FIGURES

| Figure | Title | Page |
|--------|--|------|
| 3-1 | Building Structure and Floor Amplification Factor | 3-19 |
| 3-2 | Equipment Amplification Factor | 3-20 |
| 3-3 | Force Balance Between Structure and Component..... | 3-21 |
| 3-4 | Coefficient α_1 | 3-22 |
| 3-5 | Coefficient α_2 | 3-22 |
| 3-6 | First Mode Shape of a Uniform Moment-Resisting Frame Structure | 3-23 |
| 3-7 | Equipment Amplification Factor of a Six-story Building: 5% Damping Ratio for Equipment and building Structure..... | 3-24 |
| 3-8 | Floor Response Spectrum for Secondary System Attached to Full-scale Frame Under El-Centro 1940 Earthquake: Location Effect | 3-25 |
| 3-9 | Observation Data (Different Structures) | 3-26 |
| 3-10 | Observation Data (Different Structures) | 3-27 |
| 6-1 | Seismic Design Coefficient for Parapet at Top of Building..... | 6-7 |
| 6-2 | Seismic Design Coefficient for Storage Rack at Different Locations (First Recommendation) | 6-8 |
| 6-3 | Seismic Design Coefficient for Storage Rack at Different Locations (Second Recommendation) | 6-9 |
| 6-4 | Seismic Design Coefficient for Storage Rack at Different Locations (Third Recommendation) | 6-10 |
| 6-5(a) | Seismic Design Coefficient of Equipment at Top of Building (First Recommendation)..... | 6-11 |
| 6-5(b) | Seismic Design Coefficient of Equipment at Middle of Building (First Recommendation)..... | 6-12 |

| | | |
|--------|--|------|
| 6-6(a) | Seismic Design Coefficient of Equipment at Top of Building (Second Recommendation) | 6-13 |
| 6-6(b) | Seismic Design Coefficient of Equipment at Middle of Building (Second Recommendation) | 6-14 |
| 6-7(a) | Seismic Design Coefficient of Equipment at Top of Building (Third Recommendation) | 6-15 |
| 6-7(b) | Seismic Design Coefficient of Equipment at Middle of Building (Third Recommendation) | 6-16 |
| 6-8 | Seismic Design Coefficient for Storage Rack at Top of Building | 6-17 |
| 6-9 | Seismic Design Coefficient of Equipment at Top of Building (Tuned Case) | 6-18 |
| 7-1 | Sliding Displacement | 7-7 |

LIST OF TABLES

| Table | Title | Page |
|-------|---|------|
| 3-1 | Response Modification Coefficients | 3-15 |
| 3-2 | Mechanical and Electrical Component and System Response Modification Coefficient (R_c) and Performance Criteria Factor (P) | 3-16 |
| 3-3 | Architectural Component Response Modification Coefficient (R_c) and Performance Criteria Factor (P) | 3-17 |
| 3-4 | Floor and Equipment Amplification Factors of a Test Structure | 3-18 |
| 5-1 | Mechanical and Electrical Component and System Response Modification Coefficient (R_c) and Performance Criteria Factor (P) | 5-4 |
| 5-2 | Architectural Component Response Modification Coefficient (R_c) and Performance Criteria Factor (P) | 5-5 |
| 6-1 | Maximum and Minimum Design Forces (1) | 6-5 |
| 6-2 | Maximum and Minimum Design Forces (2) | 6-5 |
| 6-3 | Parameters Used in Case Studies | 6-6 |
| 7-1 | Displacement of Flexibly-Mounted Equipment at Top of Building (Soil Type I) | 7-5 |
| 7-2 | Sliding Coefficient | 7-6 |
| A-1 | Observation Data from Selected Past Earthquakes | A-2 |

SECTION 1

INTRODUCTION

Nonstructural components anchored or attached to a building structure are generally considered as those elements that are not a part of the load-bearing structural system. They include mechanical and electrical equipment, architectural elements, and building contents. The importance of nonstructural component issues in seismic design and performance evaluation is now well recognized by researchers as well as practicing engineers. The subject received special attention after the San Fernando earthquake of 1971 when it became clear that nonstructural damage not only can result in major economic loss, but also can pose real threat to life safety.

Today, major building codes and seismic design guidelines exist which address seismic design forces for various nonstructural components. The 1991 NEHRP provisions [7] and 1991 UBC code [13], for example, are widely used for seismic design standards for nonstructural components, from which local jurisdictions and some federal agencies have developed similar seismic design requirements. In these provisions, the design force for nonstructural components is formulated as an equivalent static lateral force applied to the approximate center of gravity of the component being analyzed. While simple formulas are necessary for the sake of design applications, they contain considerable amount of arbitrariness and subjectivity which produce ambiguous results and inconsistent design forces among different codes and provisions. Furthermore, they do not reflect the level of understanding of the behavior of nonstructural components that has been achieved through theoretical analyses, experiments, and observation data from past earthquakes.

The thrust of this work is to critically assess current design force formulas for nonstructural components as they exist in the 1991 NEHRP provisions, to identify their shortcomings, and to recommend revisions which would bring them more in line with current state-of-the-knowledge in this area. These revisions are recommended within the framework of the equivalent lateral force format for practical applicability.

The 1991 NEHRP design force formulas for nonstructural components are reviewed in Section 2 and their shortcomings are identified and commented upon. Three revision recommendations based on incorporation of different levels of consideration of structural and component effects are advanced in Sections 3-5. It is shown that these revisions can

be justified on the basis of simple dynamic analyses, experimental results, and experience data.

In Section 6, these three recommended design force formulas are compared among themselves as well as in relation to existing codes and provisions. These results are further examined through case studies.

Since excessive displacements on the part of nonstructural components are causes of failure in a large number of cases during past earthquakes, the derivation of simple displacement equations for support deformation and sliding is considered in Section 7. It is recommended that this type of displacement equations be added to future codes and provisions in order to achieve a more complete seismic design scenario for nonstructural components.

SECTION 2

AN ASSESSMENT OF 1991 NEHRP PROVISIONS

2.1 Brief Summary of Current Design Forces

In 1991 NEHRP Provisions [7], as in other codes such as the 1991 UBC [13] or the 1985 Tri-Service Manual [25], seismic design forces for nonstructural components are specified in terms of static equivalent forces acting through their centers of gravity. They are described below for architectural components and for mechanical and electrical components.

2.1.1 Architectural Components

Architectural components and their means of attachment are designed for seismic forces (F_p) determined in accordance with the following equation:

$$F_p = A_v C_c P W_c \quad (2.1)$$

in which:

F_p is the seismic force applied to a component of a building at its center of gravity;

A_v is the seismic coefficient representing effective peak-velocity related acceleration from Sec. 1.4.1 of [7];

C_c is the seismic coefficient for architectural components from Table 8.2.2 of [7];

P is the performance criteria factor from Table 8.2.2 of [7]; and

W_c is the weight of the architectural component.

The force (F_p) is applied independently at vertical, longitudinal, and lateral directions in combination with the static load of the element.

2.1.2 Mechanical and Electrical Components

Mechanical and electrical components and systems are designed for seismic forces determined in accordance with the following equation:

$$F_p = A_v C_c P a_c W_c \quad (2.2)$$

in which:

F_p is the seismic force applied to a mechanical or electrical component at its center of gravity;

C_e is the seismic coefficient for mechanical and electrical components from Table 8.3.2a of [7];

P is the performance criteria factor from Table 8.3.2a of [7];

a_c is the amplification factor determined in accordance with Table 8.3.2b of [7]; and

W_e is the operating weight of the mechanical or electrical component or system.

Alternatively, the seismic forces (F_p) can be determined by a properly substantiated dynamic analysis subject to approval by the building code official.

2.1.3 Comments on the Seismic Coefficient (C_e)

The specification of the component seismic coefficient (C_e) in Eq. (2.1) was originally based on the use of the working stress design and was similar to the C_p factors specified in the UBC (1991) [13] and Title 24 of the California Administrative Code [24]. The values of C_p in the UBC (1991) [13] were set basically by professional judgement, primarily from examining the performance of equipment in past earthquakes. Some results from analyses of linear elastic multistory buildings were used to justify general relationships among the various values. Additional capacity and ductility reservations were permitted in the assignment of the C_p values [20]. Based on these observations, the determination of the C_e values is basically a subjective result from experts in the related fields and their assigned values are somewhat arbitrary.

For the design of the mechanical and electrical equipment, the seismic coefficient (C_e) in Eq. (2.2) was originally introduced to represent an amplification of the effective peak acceleration coefficient for coefficient A_v equal to or greater than 0.2 ([7], Part 2, p. 183). In order to bring C_e into conformance with other sections of the provisions. The concept was changed by defining C_e as a numerical dimensionless factor related to that for mechanical and electrical components in Table 8.3.2a of [7]. The values presented in the table were developed by adopting an analogy to the C_p values in Table T17-23-3 of Title 24 of the California Administrative Code [24] with the consistent performance criteria level of the 1991 NEHRP Provisions taken into account.

To sum up, the component seismic coefficient (C_e) in Eqs. (2.1) and (2.2) appears to be a subjectively-assigned, reflecting in part the component performance during past

strong earthquakes. The determination of this value may involve many factors, including the attachment and constraint detailing effect, transient characteristics of the seismic input, uncertainties in the determination of amplification factor (a_c), interaction between the component and its supporting structure, soil property and structural behaviors, etc. Based on different interpretations of these effects on the determination of C_s , three approaches are proposed in this report to revise formulation of the seismic design force for nonstructural components.

2.2 Shortcomings of Current Provisions

A design provision provides minimum legal design requirements for building structures. Without sacrificing simplicity for applicability to practical design, the design guidelines should reflect the state-of-the-knowledge as well as accumulated experience. As mentioned in the Introduction, the 1991 NEHRP Provisions in the area of nonstructural components have not kept in pace with current understanding of their seismic behavior through analyses, experiments, and field observations. This implies inadequacies of the current provisions in providing basic design requirements such as the minimum design forces. The major deficiency in the design force formulas for nonstructural components appears to be the negligence of their supporting structural behaviors. In particular, effects of soil type, structural period, component location and structural yielding on the nonstructural element design are not included. The anchorage detailing of the nonstructural component might be implied in the seismic coefficient (C_s) but has not been interpreted on physical grounds.

2.2.1 Soil Type Effect

In the current provisions, the design force on the nonstructural element attached to a building structure is considered to be independent of the soil type, as can be seen in Eqs. (2.1) and (2.2). Obviously, this is inconsistent with design requirements for building structures. As evidenced in the design of a building structure [7,13], soil condition has a great influence on the design base shear force for the building structure. The softer the soil layer on which the building structure is constructed, the more stringent the design requirement for the building structure. Since the seismic input to a nonstructural element is the dynamic response at its supporting locations in the building structure, its seismic response clearly depends on the properties of soils supporting the building structure. Furthermore, effects of site conditions on the design for building structures have also been amply demonstrated by past earthquake observations [26].

2.2.2 Location Effect

According to current provisions, nonstructural components located at different floors of a supporting structure are designed for the same level of force. In practice, however, nonstructural elements attached to different floors of the supporting building structure will experience different levels of acceleration. The floor amplification effect can be observed from past earthquakes as well as from analytical results as shown in Section 3.2. The inclusion of the floor amplification effect in the design force formulas of the two earlier editions of NEHRP (1985 [5] and 1988 [6]) also demonstrates the need for distinguishing design forces on nonstructural elements situated on different floors, though the effect was discarded in the 1991 edition in favor of a somewhat arbitrarily defined C_e coefficient.

2.2.3 Structural Period Effect

For the design of architectural components, the design force (F_p) in Eq. (2.1) is not considered to be related to the structural period (T_s). However, design forces on the architectural components obviously require the distinction between flexible and stiff building structures as can be seen in the base shear force formula for building structural design. For instance, a flexible structure may receive a small amount of inertia force so that an architectural component or mechanical equipment rigidly mounted to the structure are only slightly excited. As discussed in Section 3.2.3, the distribution of the acceleration or inertia force along the building height is also different for building structures with different periods.

The same is also true of the structural period effect on the design force for mechanical and electrical equipment, Eq. (2.2). Although the structural period (T_s) is incorporated into the amplification factor (a_c) in Eq. (2.2), it accounts for only partial effect that structural period has on the equipment response.

2.2.4 Structural Yielding Effect

Effects of structural yielding on the structural and nonstructural component design are considerably different. A building structure may experience inelastic deformation during severe earthquakes and, indeed, yielding of the building structure is considered as a limit state for its own design in the current provisions. However, this may not be the case for the design of nonstructural components. Failure of a nonstructural component attached to a building structure situated in a high seismic zone can occur under either of the following two cases: (1) the structure behaves inelastically under the maximum earthquake input at

the site; or (2) the structure remains elastic during a small or moderate earthquake input at the same site. Yielding of the building structure will absorb a substantial amount of energy and hence reduce the seismic force imposed on the structure, however, the seismic input energy into the nonstructural component depends both on the direct seismic energy through seismic inertia force and the transferred energy from the supporting building structure. Under a strong earthquake, the direct seismic energy from the earthquake may be large but the transferred energy from the supporting structure is usually small due to structural yielding. On the other hand, the direct seismic energy under a small or moderate earthquake is relatively small and the transferred energy can be relatively large so that the total energy received by the nonstructural component might be greater than that under a strong earthquake.

2.2.5 Anchorage Detailing Effect

Finally, anchorage detailing of nonstructural components can also have a significant influence on the design forces. As has been observed, damage of a nonstructural component in many cases results from the failure of its anchorage due to excessive stress. An appropriate design for anchorage detail can thus significantly improve the nonstructural component's performance during earthquakes. For example, the introduction of ductility capacity in the anchorage will reduce the design force.

These observations have led to three recommendations for the revision of 1991 NEHRP Provisions for architectural, mechanical, and electrical components as described in the following sections.

SECTION 3

FIRST RECOMMENDATION

In this approach, the value of C_c is considered to be affected by the interaction between the component and its supporting structure, soil properties, structural behavior, uncertainties in determination of the amplification factor, and transient characteristics of seismic input as well as the equipment detailing effect or yielding potential of mechanical or electrical equipment.

It is noted that the first four factors discussed in the shortcomings of nonstructural component design formulas outlined in Section 2.2 have been incorporated into the base shear of structural design in the current provisions. It is thus natural to take into account these effects in mechanical or electrical equipment design by transferring the vertical distribution of the base shear along the building structural height to the equipment.

3.1 Suggested Revision of the Design Force

3.1.1 Design Force Equation

Mechanical and Electrical Equipment. It is proposed that mechanical and electrical components and system be designed for seismic force determined in accordance with the following equation:

$$F_p = C_p W_c \quad (3.1)$$

in which F_p and W_c are, respectively, the seismic force applied to a nonstructural component at its center of gravity and the weight of the component as defined in the current provisions, and C_p is the seismic design coefficient of the nonstructural component which can be calculated from

$$C_p = \frac{A_v a_x a_c P}{R_s R_c} \quad (3.2)$$

where a_x is the floor amplification factor which can be determined by (see Fig. 3-1)

$$a_x = 1 + \frac{h_x}{h_n} (a_n - 1) \quad (3.3)$$

with

$$a_n = 1.5 \beta_s \geq 1 \quad (3.4)$$

and

$$\beta_s = \frac{1.2S}{T_s^{2/3}} \leq \frac{2.5A_a}{A_v} \quad (3.5)$$

in which S is the site coefficient from Table 3-2 in [7], A_v and A_a are, respectively, the effective peak velocity-related acceleration and the effective peak acceleration from Section 1.4.1 of [7], and T_s is the structural period determined in Section 4.2.2 of [7].

The factor a_c in Eq. (3.2), a function of period ratio (T_c/T_s) between equipment and its supporting structure, is the equipment amplification factor which can be calculated by (see Fig. 3-2)

$$a_c = \begin{cases} 1.0, & T_c/T_s \leq 0.5 \text{ and } T_c/T_s \geq 2.0 \\ 2.5, & 0.7 \leq T_c/T_s \leq 1.4 \\ -2.75 + 7.5(T_c/T_s), & 0.5 < T_c/T_s < 0.7 \\ 6 - 2.5(T_c/T_s), & 1.4 < T_c/T_s < 2.0 \end{cases} \quad (3.6)$$

The factor R_s in Eq. (3.2) is the response modification coefficient for component design due to structural yielding which can be estimated from the response modification coefficient for structural design (R) in Table 3-3 of [7] by

$$R_s = 1 + \frac{R - 1}{7} \quad (3.7)$$

Its values are tabulated in Table 3-1 in this report for different types of buildings. In Eq. (3.2), the performance criteria factor (P) takes different values than those in the current provisions as shown in Table 3-2 and R_c is the response modification coefficient due to component yielding which is tentatively presented in Table 3-2.

Architectural Components. For architectural components, the design force (F_p) is again expressed by Eq. (3.1) except that the equipment amplification factor (a_c) is assigned to be 1.0 and the performance criteria factor (P) and the response modification coefficient (R_c) take different values as presented in Table 3-3.

3.1.2 Development of the Design Force Equation

In this section, the formulation of C_p in Eq. (3.2) is discussed in detail. Since C_p is closely related to the base shear and force distribution of the supporting structure, formulas for their calculations are also given.

Base Shear Force for Structure. The seismic base shear force (V) of the building structure in a given direction is provided by Eq. (4-1) in [7], i.e.,

$$V = C_s(W_s + W_c) \quad (3.8)$$

in which W_s is the total dead load and applicable portion of other loads on the building structure and the seismic design coefficient C_s can be written as (Eq. (4-2) of [7])

$$C_s = \beta_s \cdot \frac{A_v}{R_s} \quad (3.9)$$

Here, R_s is the modified response modification coefficient (R) for building structures defined in Table 3-3 of [7]. This modification is necessary because the reserve capacity for building structure design due to nonstructural element constraint and unnecessary redundancy no longer exists for nonstructural element design and the ductility capacity for structural design is not totally transferable to the nonstructural component design. A very simple modification would be to shrink the response modification coefficient (R 's) for structural design into the range from 1.0 to 2.0 for nonstructural component design as given in Eq. (3.7). The quantity β_s is a coefficient which is actually related to the seismic response spectrum as given by Eq. (3.5), which is derived from Eq. (4-2) of [7].

Vertical Distribution of Base Shear Force. As shown in Fig. 3-3, the total base shear force (V) is balanced by the seismic force on mechanical and electrical equipment (F_p) and the inertia force on building floors (F_i , $i = 1, 2, \dots, n$), i.e.,

$$V = F_p + \sum_{i=1}^n F_i \quad (3.10)$$

Assuming that the inertia force acting on a given floor is proportional to the floor height multiplied by its floor weight as in the structural design in the current provisions, the inertia force acting on the floor at h_x level can be then formulated as

$$F_x = C_{vx}(V - F_p) \quad (3.11)$$

in which the vertical distribution factor (C_{vx}) can be expressed as

$$C_{vx} = \frac{W_x(h_x + h_0)}{\sum_{i=1}^n W_i(h_i + h_0)} = \frac{W_x a_x}{\sum_{i=1}^n W_i a_i} \quad (3.12)$$

and

$$h_0 = \frac{h_n}{a_n - 1} \quad (3.13)$$

as denoted in Fig. 3-1. The quantity h_0 is introduced because the acceleration distribution along building height is trapezoidal instead of triangular as will be illustrated in Section 3.2.

Design Force on Equipment at h_x Level. The floor acceleration can be calculated by dividing the lateral force (F_x) by its floor mass. This acceleration is amplified by a_c to obtain the equipment acceleration which is then multiplied by equipment mass to arrive at the design force on the equipment attached to the floor at h_x level, i.e.,

$$F_p = \left(\frac{F_x}{W_x} \right) a_c W_c \quad (3.14)$$

or

$$F_x = \frac{W_x F_p}{W_c a_c} \quad (3.15)$$

As one can see from Eqs. (3.11) and (3.12), the ratio of the inertia forces between the i th floor and the x th floor is

$$\frac{F_i}{F_x} = \frac{W_i a_i}{W_x a_x} \quad (3.16)$$

By substituting Eq. (3.15) for F_x in Eq. (3.16), the inertia force on the i th floor (F_i) can be expressed as

$$F_i = \frac{W_i a_i}{W_x a_x} F_x = \frac{W_i a_i}{W_c a_c a_x} F_p \quad (3.17)$$

Consequently, the seismic force on the equipment (F_p) can be determined by introducing Eq. (3.17) into Eq. (3.10), giving

$$F_p = \frac{V}{1 + \frac{1}{a_c a_x} \sum_{i=1}^n \frac{W_i}{W_c} a_i} = \frac{A_v a_c a_x W_c}{R_s} \alpha_1 \alpha_2 \quad (3.18)$$

in which

$$\alpha_1 = \frac{\beta_s}{\sum_{i=1}^n \frac{W_i}{W_s} a_i} \quad (3.19)$$

$$\alpha_2 = \frac{\left(1 + \frac{W_c}{W_s}\right) \sum_{i=1}^n \frac{W_i}{W_s} a_i}{\frac{W_c}{W_s} a_c a_x + \sum_{i=1}^n \frac{W_i}{W_s} a_i} \quad (3.20)$$

where Eqs. (3.8) and (3.9) have been employed.

For a uniform building structure, i.e., $W_s = nW_1$ and $h_n = nh_1$, coefficients α_1 and α_2 can be respectively written as

$$\alpha_1 = \frac{2\beta_s}{a_n + 1 + (a_n - 1)/n} \quad (3.21)$$

$$\alpha_2 = \frac{\left(1 + \frac{W_c}{W_s}\right) \left(\frac{a_n+1}{2} + \frac{a_n-1}{2n}\right)}{\frac{W_c}{W_s} a_c a_x + \frac{a_n+1}{2} + \frac{a_n-1}{2n}} \quad (3.22)$$

When a moment-resistent frame structure with the estimated fundamental period (T_s) equal to 0.1n sec (Eq. (4-4a) of [7]) is constructed on soil layer of type 1, coefficient α_1 is plotted in Fig. 3-4 against structural period T_s . As one can see, α_1 almost remains constant and is approximately equal to 0.9. Therefore, coefficient α_1 can be approximately set to 1.0 for simple design purposes for this type of uniform structures.

Equation (3.22) shows that coefficient α_2 is a function of mass ratio W_c/W_s , period ratio T_c/T_s implied in a_c , and position x expressed by a_x , which can be defined as an interaction factor. When $a_x \cong [a_n + 1 + (a_n - 1)/n]/2$, interaction factor α_2 is plotted in Fig. 3-5 as a function of mass ratio W_c/W_s for both detuned and tuned cases, indicating that seismic force acting on an equipment ($W_c = 0.1W_s$) can be reduced by about 12% due to the interaction effect in the tuned case. Following simplicity requirements for practical design, the interaction effect can be neglected for light equipment and therefore the seismic force on the equipment is simply represented by

$$F_p = \frac{A_v a_x a_c W_c}{R_s} \quad (3.23)$$

Ductility Capacity of Equipment. As in structural design, the seismic force in Eq. (3.23) can be reduced by a factor R_c for equipment design due to potential ductility capacity in the equipment anchorage, hence,

$$F_p = \frac{A_v a_x a_c W_c}{R_s R_c} \quad (3.24)$$

Performance Criteria Factor. By considering the performance criteria factor (P) for equipment, the design force on the equipment can be finally formulated as

$$F_p = \frac{A_v a_x a_c P W_c}{R_s R_c} = C_p W_c \quad (3.25)$$

3.1.3 Performance Criteria Factor (P) and Response Modification Coefficient (R_c)

As illustrated by the derivations given above, characteristics of an integrated system consisting of nonstructural elements and building structure show that the nonstructural element performance during earthquakes can be considerably improved. Impact of the nonstructural element importance (or function) on the design of the nonstructural element should therefore be not as significant as that in the current provisions. The values of 0.8, 1.0, 1.2 for the performance criteria factor (P) are thus suggested for architectural components as well as mechanical and electrical components with seismic

hazard exposure group I, II, and III, respectively. The specific values of P for different nonstructural elements can be obtained by modification of the number in Tables 8-2-2 and 8-3-2(a) of [7] and are retabulated in Tables 3-2 and 3-3 here.

The response modification coefficients (R_c 's) can be determined by following two steps: (1) direct transfer of the seismic coefficients (C_c) in the current provisions to \bar{R}_c and (2) modification of the obtained values (\bar{R}_c) to obtain R_c . Here, \bar{R}_c accounts for effects of both structure and component on the design force of the nonstructural component; whereas R_c takes into account the nonstructural component effects only. The relationship between R_c and \bar{R}_c can be simply established as

$$R_c = 1 + \frac{2}{3.5}(\bar{R}_c - 1) \quad (3.26)$$

which compresses the range (1 - 4.5) of \bar{R}_c into the range (1 - 3) of R_c . The determination of \bar{R}_c is discussed in Section 5.1.3.

3.1.4 Comments on Structural Yielding Effect

As pointed out in Section 2.2.4, structural yielding does not necessarily cause the maximum seismic force acting on a nonstructural component attached to the structure. This phenomenon is not reflected in the design force formula (Eq. (3.1)) for simplicity. If warranted, this effect can be included in the design force computation by adding the constraint

$$\frac{A_v}{R_s} \geq \min(A_v, A_{vy}) \quad (3.27)$$

in which A_{vy} denotes the peak velocity-related acceleration resulting in structural yielding. In an earthquake-prone area, A_v could be larger than A_{vy} and Eq. (3.27) basically means that the larger of the input accelerations of a structure in the inelastic state and in the initial yielding state should be used as the input for nonstructural component design.

3.2 Justifications

In formulating the recommended revision to the current provisions, efforts have been made to incorporate into the revision the latest theoretical research results and available experimental results as well as building response observation data and reconnaissance reports of recent earthquakes.

3.2.1 Theoretical Analyses

Modal Shapes and Mass Distribution Factor. For a uniform moment-resisting frame structure as shown in Fig. 3-1, the equation of motion is given by

$$\mathbf{M}\ddot{\mathbf{y}}(t) + \mathbf{C}\dot{\mathbf{y}}(t) + \mathbf{K}\mathbf{y}(t) = -\mathbf{M}\mathbf{e}\ddot{x}_g(t) \quad (3.28)$$

in which \mathbf{M} , \mathbf{C} , and \mathbf{K} are the mass, damping, and stiffness matrices of an n -story structure; \mathbf{e} is the index vector of earthquake input; and $\mathbf{y}(t)$ is the relative displacement of the structure with respect to the ground. The fundamental period of the structure can be analytically calculated by [8]

$$T_s = \frac{T_0}{2 \sin \left(\frac{\pi}{2(2n+1)} \right)} \quad (3.29)$$

in which T_0 is the period of its associated one-story building. The mode shape associated with the first mode can be analytically formulated as

$$\phi(n) = 1 \quad (3.30)$$

$$\phi(n-1) = 1 - \lambda_1 \quad (3.31)$$

$$\phi(i) = (2 - \lambda_1)\phi(i+1) - \phi(i+2), \quad i = 1, 2, \dots, n-2 \quad (3.32)$$

where

$$\lambda_1 = \left(\frac{T_0}{T_s} \right)^2 \quad (3.33)$$

The first mode shape is shown in Fig. 3-6 for buildings with different numbers of stories (n). It can be observed that the mode shape of a frame system is quite stable as the number of story increases and can be approximated by a straight line.

When the first mode shape is assumed to be a straight line, the i th element of mode shape vector ϕ can be simply expressed as

$$\phi(i) = \frac{i}{n} \quad (3.34)$$

and the modal mass and participation factor can be formulated as

$$m_1 = \phi^T \mathbf{M} \phi = m \sum_{i=1}^n \left(\frac{i}{n} \right)^2 = \frac{m(n+1)(2n+1)}{6n} \quad (3.35)$$

$$\phi \mathbf{M} \mathbf{e} = m \sum_{i=1}^n \frac{i}{n} = \frac{m(n+1)}{2} \quad (3.36)$$

$$\Gamma_1 = \frac{\phi^T \mathbf{M} \mathbf{e}}{\phi^T \mathbf{M} \phi} = \frac{3n}{2n+1} \quad (3.37)$$

The mass distribution factor $\phi(n)\Gamma_1$ can then be formulated as

$$\phi(n)\Gamma_1 = \frac{3n}{2n+1} \quad (3.38)$$

which approaches 1.5 for large n , i.e., the factor used in Eq. (3.4).

Absolute Acceleration or Inertia Force Distribution over Building Height. The equation of motion of the first-mode representation of a multi-degree-of-freedom (MDOF) building structure can be expressed by

$$\ddot{y}_x(t) + 2\xi_1\omega_1\dot{y}_x(t) + \omega_1^2 y_x(t) = -\phi(x)\Gamma_1\ddot{x}_g(t) \quad (3.39)$$

in which $y_x(t)$ is the relative displacement of the structure at h_x level and can be further expressed by

$$y_x(t) = \phi(x)\Gamma_1 q(t) \quad (3.40)$$

$$\ddot{q}(t) + 2\xi_1\omega_1\dot{q}(t) + \omega_1^2 q(t) = -\ddot{x}_g(t) \quad (3.41)$$

The absolute acceleration of the structure at h_x level can thus be formulated as

$$\ddot{y}_x(t) + \ddot{x}_g(t) = \phi(x)\Gamma_1[\ddot{q}(t) + \ddot{x}_g(t)] + [1 - \phi(x)\Gamma_1]\ddot{x}_g(t) \quad (3.42)$$

from which one can readily observe that vertical distribution of the absolute acceleration is trapezoidal if the first mode shape $\phi(x)$ is assumed to be a straight line. At the base of the building structure, $\phi(x) = 0$ and $\ddot{y}_x(t) + \ddot{x}_g(t) = \ddot{x}_g(t)$, which is exact. The floor amplification factor (a_0) in this case is equal to unity. At the top of the structure, the first term in Eq. (3.42) is predominant and therefore the floor amplification factor a_n is approximately equal to the acceleration response spectrum calculated by Eq. (3.41) multiplied by a mass distribution factor $\phi(n)\Gamma_1$. This is the theoretical foundation of Eq. (3.4).

Amplification Factor (a_c) and Mass Ratio Effect. The equation of motion for a coupled system with a single-degree-of-freedom (SDOF) representation of the equipment and a SDOF representation of the MDOF structural system can be written as

$$m_x[\ddot{y}_x(t) + 2\xi_1\omega_1\dot{y}_x(t) + \omega_1^2 y_x(t)] - m_c[2\xi_c\omega_c\dot{z}(t) + \omega_c^2 z(t)] = -\phi(x)\Gamma_1 m_x\ddot{x}_g(t) \quad (3.43)$$

$$m_c[\ddot{z}(t) + 2\xi_c\omega_c\dot{z}(t) + \omega_c^2 z(t)] = -m_c[\ddot{y}_x(t) + \ddot{x}_g(t)] \quad (3.44)$$

in which the modal mass of the structure represented by the relative displacement at h_x level is calculated by

$$m_x = \frac{\phi^T \mathbf{M} \phi}{\phi^2(x)} \quad (3.45)$$

m_c , ξ_c , and ω_c are the equipment mass, damping ratio, and frequency, respectively, and $z(t)$ is the relative displacement of the equipment with respect to the building floor at h_x level.

The root-mean-square ratio between absolute accelerations of the equipment and the first mode representation of a six-story uniform moment-resisting frame structure subjected to seismic excitation with the Kanai-Tajimi spectrum (an indication of amplification factor for equipment subjected to random loadings) is plotted in Fig. 3-7 as a function of the period ratio (T_c/T_s) and for different mass ratios (m_c/m_x) and different $\phi(x)\Gamma_1$'s due to different equipment locations. The Kanai-Tajimi spectrum has the form

$$S_{\ddot{x}_g}(\omega) = S_o \frac{1 + 4\xi_g^2 \left(\frac{\omega}{\omega_g}\right)^2}{\left(1 - \frac{\omega^2}{\omega_g^2}\right)^2 + 4\xi_g^2 \left(\frac{\omega}{\omega_g}\right)^2} \quad (3.46)$$

with parameters $S_o = 1$, $\xi_g = 0.64$, $\omega_g = 15.6$ rad/sec [12].

Further examination of Eqs. (3.43) and (3.45) shows that both the mass ratio (m_c/m_x) and the mass distribution factor ($\phi(x)\Gamma_1$) increase when floor number on which the equipment is installed increases. The increase of the mass ratio means a reduction of the equipment amplification factor (a_c) due to interaction effect while the increase of the mass distribution factor results in greater equipment amplification factor. The question as to whether the floor amplification factor (a_x) and the equipment amplification factor (a_c) in the design force formula can be separately considered is therefore posed here. A very preliminary conclusion can be drawn from Fig. 3-7, which shows that the equipment amplification factor (a_c) can be approximately determined independent of location of the equipment. This supports the derivation process for the design force in the suggested approach.

Uncertainty Effect on the Determination of Amplification Factor (a_c). In the above, the equipment amplification factor (a_c) of a six-story building structure has been evaluated individually. For design purposes, however, a simpler but more general formulation for a_c

is needed. The simplest model for a_c would include the determination of both amplitude and broadened band associated with the equipment response spectrum in the tuned case.

The response of mechanical or electrical equipment located on ground or on a very rigid structure is mainly a function of the frequency content of the postulated earthquake, whereas the response of the equipment attached to a relatively flexible structure is mainly a function of the structure's natural periods. The supporting structure in this case acts as a filter amplifying the seismic motion at its own natural periods. The statistical characteristics of the equipment response during a seismic disturbance in the first case can be well described by the design response spectrum value (β_s), while the equipment response on a flexible structure can be simply described as the harmonic response oscillating at the fundamental structural period. The reality for the determination of a_c is between the above two extreme cases. Based on these observations, we consider the amplitude of a_c for all period ratios between the equipment and the structure to be not less than 2.5.

Due to uncertainties involved in the structural parameters such as mass, stiffness, and damping ratio, the peak value of a_c (commonly called floor response spectrum) needs to be broadened for design purposes. According to the analyses performed for nuclear power plant design [1], coefficients of variation (Cov) of 5-10% for mass determination and about 34% for stiffness determination are appropriate. In what follows, coefficients of variation of the structural period and the equipment period are simply evaluated by assuming perfect correlation between masses at different floors or between stiffnesses at different floors. In this case, the fundamental period of the structure can be calculated by Eq. (3.29) but T_0 in the formula is a random variable.

When mass and stiffness of a uniform structure are considered as two independent lognormal random variables, the coefficient of variation for its fundamental period, $\text{Cov}(T_s)$, can be calculated from the coefficient of variation of mass, $\text{Cov}(M)$, and of stiffness, $\text{Cov}(K)$, by the following equation:

$$\text{Cov}(T_s) = \sqrt{[1 + (\text{Cov}(M))^2]^{1/4} [1 + (\text{Cov}(K))^2]^{1/4} - 1} \quad (3.47)$$

Substituting $\text{Cov}(M) = 0.10$ and $\text{Cov}(K) = 0.34$ into Eq. (3.47), we can calculate the coefficient of variation for the structural period, i.e., $\text{Cov}(T_s) = 0.174$. The structural period (T_s) in this case is also lognormal. Assuming that the equipment period (T_c) has the same coefficient of variation as the structural period but is independent of T_s , the coefficient of

variation of the period ratio between the equipment and the structure can be subsequently calculated as

$$\text{Cov}(T_c/T_s) = \sqrt{[1 + (\text{Cov}(T_c))^2][1 + (\text{Cov}(T_s))^2] - 1} \quad (3.48)$$

$$= \sqrt{(1 + 0.174^2)^2 - 1} = 0.248 \quad (3.49)$$

Considering nonuniformity of mass and stiffness distributions along the building height, imperfectly-correlated properties associated with masses or stiffnesses at different floors, possible higher-mode effects, and other uncertainty factors such as damping coefficients as well as the fact that both $\text{Cov}(K)$ and $\text{Cov}(M)$ might be larger for regular building structures, a coefficient of variation of 30% for the period ratio (T_c/T_s) is suggested. That is, the peak value of a_c can be broadened into the range of 0.7 to 1.3. However, sensitivity of the period ratio to uncertainties existed in the equipment-structure system is often stronger for flexible equipment than for stiff equipment and the amplification factor always skews toward the larger period ratio (T_c/T_s) as illustrated in Fig. 3-7. The peak value is finally recommended to be broadened to the range of 0.7 to 1.4. From recent research on decoupling criteria between equipment and structure [8] and other related research results, the interaction effect outside the range of 0.5 to 2.0 for the period ratio is negligible. Consequently, the amplification factor (a_c) can be calculated by Eq. (3.6) and is shown in Fig. 3-2.

Structure Yielding Effect. Limited investigations on the structure yielding effect [9,22] consistently demonstrate a reduction of the dynamic response of an equipment when the supporting structure behaves inelastically during severe earthquakes. The introduction of the response modification coefficient (R_s) is attributed to the different degrees of ductility capacities of structures. On the other hand, information on equipment response reduction due to structural yielding is less than that available for the structure itself [17]. It seems reasonable to define the available reduction coefficient (R_s) for nonstructural component design as a value ranging from 1.0 to 2.0, which is Eq. (3.7).

3.2.2 Experimental Results

Compared with extensive analytical work on the structure-equipment system interaction, small-scale or full-scale experimental evidence seems to be scant [9]. Experimental results reported in [14-16,18] played a role in the development of the proposed procedure in this report.

The experimental model used in [15] was a five-story, one-third scale frame structure with first three periods of 0.308, 0.180, and 0.082 seconds. This model structure was subjected to four typical earthquake input signals based on records of historical California earthquakes, i.e., the El Centro 1940 NS component, the Pacoima Dam 1971 S16E component, the Taft 1950 S69E component, and the Parkfield 1966 N65E component. Each signal was run in real time and time-scaled by a factor of $\sqrt{3}$, which corresponds to the geometrical scale of the model. The response of the model to these time-scaled inputs should correspond to that of a full-scale structure to the historical earthquakes. Three oscillators, simple vertical cantilevers, were used in the test to simulate light equipment. Oscillators 1 and 2 were attached to the top floor and oscillator 3 was supported at the second floor of the model structure. Their vibrational periods were respectively taken as 0.308, 0.180, and 0.67 seconds, the first two of which were tuned to the first and second modes of the model structure.

The floor amplification factors (a_x) at the top and second floors of the model structure as well as the equipment amplification factors (a_c) of the three oscillators are calculated and tabulated in Table 3-4 for both real time and time-scaled signals. As one can see, the top floor amplification factor (a_5) varies from a low of 2.7 for both the Pacoima Dam time-scaled and the Parkfield real time signals to a high of 4.8 for the El Centro and Parkfield time-scaled signals. These amplifications have a mean of 3.46 and a coefficient of variation of 0.276, which support the maximum value of 3.75 for a_n in Eq. (3.4). Furthermore, the values of ratio a_2/a_5 in the last column of Table 3-4 have a mean of 0.639, which roughly agrees with the value 0.56 calculated from Eq. (3.3). The larger statistical value of a_2/a_5 from the experimental results may be due to the straight line assumption used for the first mode shape of the experimental structure in Eq. (3.3) as well as higher-mode contribution which is especially significant to the response at lower floors. It can also be observed that values of the equipment amplification factor (a_c) have a mean of 2.996 for oscillator 1 tuned to the structural fundamental mode and a mean of 1.913 for oscillator 2 which is detuned to the fundamental mode but tuned to the second mode of the structure. The larger equipment amplification factor (2.431) for oscillator 3 over oscillator 2 further illustrates the higher-mode involvement in lower floor's response.

In the experiment reported in [18], a three-story, one-quarter scaled frame was used to model the building structure and a cantilevered damper was used to represent the component. The shaking table test results show that the interaction effect between structure and equipment is significant in the tuned cases and a numerical calculation scheme can predict equipment response that agrees well with the experimental results.

The floor response spectrum for a full-scaled equipment converted from the scaled model was calculated numerically for different equipment locations and is shown in Fig. 3-8. Obviously, the floor response spectrum strongly depends on the equipment location in tuned cases, which supports the proposed formula of the design force here.

3.2.3 Observations on Past Earthquakes

Many observations on the structural behavior during earthquakes have been conducted in the past two decades. Most of them were made in California during a few major earthquakes such as the San Fernando earthquake on February 9, 1971, the Whittier earthquake on October 1, 1987, and the Loma Prieta earthquake on October 17, 1989. These observation data are used here to perform a statistical analysis on the amplification factor (a_n) for different types of buildings. Figure 3-9 presents the amplification factors (a_n) for different types of buildings (steel frame, reinforced concrete frame, and R-C shear wall) with various structural periods (T_s). It can be seen from this plot that the observed data are quite dispersive. This dispersion mainly results from the fact that the soil layer on which the structure is located and the seismic intensity to which the structure is subjected are not distinguished. Different degrees of structural yielding involved during these earthquakes may further complicate the distribution of the observed data. Nevertheless, the proposed floor amplification factor (a_n) in Eq. (3.4) for soil conditions of type IV (solid line in Fig. 3-9) almost envelopes the dispersive observation data.

Figure 3-10 presents the same set of observed amplification factors (a_n) as a function of building structural period (T_s) relative to the different earthquake events. It can be seen that most observed data are from the more recent earthquakes such as the Loma Prieta earthquake.

Similar statistical analyses for the amplification factor have been conducted elsewhere [10,21] and the trapezoidal acceleration distribution along a building height has also been observed.

3.2.4 Related Design Codes

As mentioned in Section 2.2, the earlier NEHRP provisions (1985, 1988) employed an amplification factor (a_x) to distinguish different degrees of response magnification when an equipment is installed at different floors of a building. The deletion of this factor in the current provisions only reinforces difficulties in reaching a good understanding of the component seismic coefficient (C_c). As more experience data about component behavior

during earthquakes are accumulated, a better understanding of the floor amplification factor (a_x) can be achieved.

The Japanese code [11] for nonstructural component design also introduces the floor amplification factor (a_x) as expressed in Eq. (3.3) but the amplification factor (a_n) at the top of a building structure is bounded by a factor of 10/3 instead of $1.5 \times 2.5 (= 3.75)$ in this report, which is more justifiable. In addition, the expression for a_n in the Japanese code is independent of soil conditions.

TABLE 3-1. Response Modification Coefficients

| Basic Structural System and Seismic Force Resisting System | for Component Design, R_s | for Structural Design, R |
|---|-----------------------------|----------------------------|
| Bearing Wall System | | |
| Light frame walls with shear panels | 1.8 | 6.5 |
| Reinforced concrete shear walls | 1.5 | 4.5 |
| Reinforced masonry shear walls | 1.4 | 3.5 |
| Concentrically braced frames | 1.4 | 4.0 |
| Unreinforced masonry shear walls | 1.0 | 1.25 |
| Building Frame System | | |
| Eccentrically braced frames, moment resisting connections at columns away from link | 2.0 | 8.0 |
| Eccentrically braced frames, non-moment resisting connections at columns away from link | 1.9 | 7.0 |
| Light frame walls with shear panels | 1.9 | 7.0 |
| Concentrically braced frames | 1.6 | 5.0 |
| Reinforced concrete shear walls | 1.6 | 5.5 |
| Reinforced masonry shear walls | 1.5 | 4.5 |
| Unreinforced masonry shear walls | 1.0 | 1.5 |
| Moment Resisting Frame System | | |
| Special moment frames of steel | 2.0 | 8.0 |
| Special moment frames of reinforced concrete | 2.0 | 8.0 |
| Intermediate moment frames of reinforced concrete | 1.4 | 4.0 |
| Ordinary moment frames of steel | 1.5 | 4.5 |
| Ordinary moment frames of reinforced concrete | 1.1 | 2.0 |
| Dual System with a Special Moment Frame Capable of Resisting at Least 25% Prescribed Seismic Forces | | |
| Eccentrically braced frames, moment resisting connections at columns away from link | 2.0 | 8.0 |
| Eccentrically braced frames, non-moment resisting connections at columns away from link | 1.9 | 7.0 |
| Concentrically braced frames | 1.7 | 6.0 |
| Reinforced concrete shear walls | 2.0 | 8.0 |
| Reinforced masonry shear walls | 1.8 | 6.5 |
| Wood sheathed shear panels | 2.0 | 8.0 |
| Dual System with an Intermediate Moment Frame of Reinforced Concrete or an Ordinary Moment Frame of Steel Capable of Resisting at Least 25% of Prescribed Seismic Forces | | |
| Concentrically braced frames | 1.6 | 5.0 |
| Reinforced concrete shear walls | 1.7 | 6.0 |
| Reinforced masonry shear walls | 1.6 | 5.0 |
| Wood sheathed shear panels | 1.9 | 7.0 |
| Inverted Pendulum Structures--Seismic Force Resisting System | | |
| Special moment frames of structural steel | 1.2 | 2.5 |
| Special moment frames of reinforced concrete | 1.2 | 2.5 |
| Ordinary moment frames of structural steel | 1.0 | 1.25 |

TABLE 3-2. Mechanical and Electrical Component and System Response Modification Coefficient (R_c) and Performance Criteria Factor (P)

| Mechanical and Electrical Component or System | Response Modification Coefficient (R_c) | Performance Criteria Factor (P) [new(old)] | | |
|--|---|--|-----------------------------|----------------------------------|
| | | Seismic | Hazard | Exposure Group |
| | | I | II | III |
| Fire protection equipment and systems | 1.1 | 1.2(1.5) | 1.2(1.5) | 1.2(1.5) |
| Emergency or standby electrical systems | 1.1 | 1.2(1.5) | 1.2(1.5) | 1.2(1.5) |
| Elevator drive, suspension system, and control anchorage | 1.6 | 1.0 | 1.0 | 1.2(1.5) |
| General equipment Boilers, furnaces, incinerators, water heaters, and other equipment using combustible energy sources or high temperature energy sources chimneys, flues, smokestacks, and vents Communication systems Electrical bus ducts, conduit, and cable trays Electrical motor control centers, motor control devices, switchgears, transformers, and unit substations Reciprocating or rotating equipment Tanks, heat exchangers, and pressure vessels Utility and service interfaces | 1.1 | 0.8(0.5) | 1.0 | 1.2(1.5) |
| Manufacturing and process machinery | 2.7 | 0.8(0.5) | 1.0 | 1.2(1.5) |
| Pipe systems Gas and high hazard piping Fire suppression piping Other pipe systems | 1.1 1.1 2.7 | 1.2(1.5) 1.2(1.5) NR | 1.2(1.5) 1.2(1.5) 1.0 | 1.2(1.5) 1.2(1.5) 1.2(1.5) |
| HVAC and service ducts | 2.7 | NR | 1.0 | 1.2(1.5) |
| Electrical panel boards and dimmers | 2.7 | NR | 1.0 | 1.2(1.5) |
| Lighting fixtures | 2.7 | 0.8(0.5) | 1.0 | 1.2(1.5) |
| Conveyor systems (nonpersonnel) | 2.7 | NR | NR | 1.2(1.5) |

TABLE 3-3. Architectural Component Response Modification Coefficient (R_c) and Performance Criteria Factor (P)

| Architectural Component | Response Modification Coefficient (R_c) | Performance Criteria Factor (P) [new(old)] | | |
|---|---|--|----------|----------------|
| | | Seismic | Hazard | Exposure Group |
| | | I | II | III |
| Exterior nonbearing walls | 2.1 | 1.2(1.5) | 1.2(1.5) | 1.2(1.5) |
| Interior nonbearing walls | | | | |
| Stair enclosures | 1.5 | 1.0 | 1.0 | 1.2(1.5) |
| Elevator shaft enclosures | 1.5 | 0.8(0.5) | 0.8(0.5) | 1.2(1.5) |
| Other vertical shaft enclosures | 2.1 | 1.0 | 1.0 | 1.2(1.5) |
| Other nonbearing walls | 2.1 | 1.0 | 1.0 | 1.2(1.5) |
| Cantilever elements | | | | |
| Parapets, chimneys, or stacks | 1.0 | 1.2(1.5) | 1.2(1.5) | 1.2(1.5) |
| Wall attachments (see Sec. 8.2.3) | 1.0 | 1.2(1.5) | 1.2(1.5) | 1.2(1.5) |
| Veneer connections | 1.0 | 0.8(0.5) | 1.0 | 1.0 |
| Penthouses | 3.0 | NR | 1.0 | 1.0 |
| Structural fireproofing | 2.1 | 0.8(0.5) | 1.0 | 1.2(1.5) |
| Ceilings | | | | |
| Fire-rated membrane | 2.1 | 1.0 | 1.0 | 1.2(1.5) |
| Nonfire-rated membrane | 3.0 | 0.8(0.5) | 1.0 | 1.0 |
| Storage racks more than 8 feet in height (content included) | 1.5 | 1.0 | 1.0 | 1.2(1.5) |
| Access floors (supported equipment included) | 1.1 | 0.8(0.5) | 1.0 | 1.2(1.5) |
| Elevator and counterweight guiderails and supports | 1.6 | 1.0 | 1.0 | 1.2(1.5) |
| Appendages | | | | |
| Roofing units | 3.0 | NR | 1.0 | 1.0 |
| Containers and miscellaneous components (free standing) | 1.5 | NR | 1.0 | 1.0 |
| Partitions | | | | |
| Horizontal exits including ceiling | 2.1 | 1.0 | 1.2(1.5) | 1.2(1.5) |
| Public corridors | 2.1 | 0.8(0.5) | 1.0 | 1.2(1.5) |
| Private corridors | 3.0 | NR | 0.8(0.5) | 1.2(1.5) |
| Full height area separation partitions | 2.1 | 1.0 | 1.0 | 1.2(1.5) |
| Full height other partitions | 3.0 | 0.8(0.5) | 0.8(0.5) | 1.2(1.5) |
| Partial height partitions | 3.0 | NR | 0.8(0.5) | 1.0 |

TABLE 3-4. Floor and Equipment Amplification Factors of a Test Structure

| signal | input | a_5 (5th fl) | a_2 (2nd fl) | a_c (osc. 1) | a_c (osc. 2) | a_c (osc. 3) | a_2/a_5 |
|--------------------------|-----------|----------------|----------------|----------------|----------------|----------------|-----------|
| real time | El Centro | 3.890 | 1.940 | 2.815 | 2.030 | 2.362 | 0.4986 |
| | Taft | 3.454 | 1.923 | 5.385 | 1.643 | 1.090 | 0.5567 |
| | Pacoima | 3.549 | 2.126 | 2.449 | 2.998 | 2.547 | 0.5990 |
| | Parkfield | 2.685 | 1.750 | 4.215 | 1.466 | 3.306 | 0.6519 |
| time-scaled | El Centro | 4.737 | 2.267 | 1.626 | 1.247 | 0.952 | 0.4785 |
| | Taft | 1.855 | 1.879 | 3.687 | 2.984 | 4.036 | 1.0129 |
| | Pacoima | 2.706 | 1.820 | 1.558 | 1.503 | 2.446 | 0.6728 |
| | Parkfield | 4.776 | 3.058 | 2.235 | 1.430 | 2.709 | 0.6403 |
| mean | | 3.460 | 2.095 | 2.996 | 1.913 | 2.431 | 0.639 |
| coefficient of variation | | 0.276 | 0.189 | 0.418 | 0.344 | 0.396 | 0.244 |




Fig. 3-1 Building Structure and Floor Amplification Factor




Fig. 3-2 Equipment Amplification Factor




Fig. 3-3 Force Balance Between Structure and Component




Fig. 3-4 Coefficient α_1




Fig. 3-5 Coefficient α_2




Fig. 3-6 First Mode Shape of a Uniform Moment-Resisting Frame Structure




Fig. 3-7 Equipment Amplification Factor of a Six-Story Building:
5% Damping Ratios for Equipment and Building Structure




Fig. 3-8 Floor Response Spectrum for Secondary System Attached to Full-Scale Frame Under El-Centro 1940 Earthquake:
Location Effect (Taken from [18])

Base to Roof Acceleration Amplification Factor--Observation from California Earthquakes




Fig. 3-9 Observation Data (Different Structures)

Base to Roof Acceleration Amplification Factor--Observation from California Earthquakes




Fig. 3-10 Observation Data (Different Earthquakes)

SECTION 4

SECOND RECOMMENDATION

The integrated behavior of the nonstructural component and its supporting structure has been considered in the formulation of the first recommendation. Hence, explicit information concerning the component, such as its response modification coefficient (R_c) and its period (T_c) is required. In certain situations, component-specific information may not be available. Therefore, a completely structure-driven design methodology for nonstructural components is useful in practice, i.e., parameters such as R_c and T_c do not appear explicitly in the design force equation. This methodology is also supported by the argument that two different light equipment with equal weight, attached to a heavy building floor, will receive approximately the same amount of inertia force except for perfectly tuned cases which have a low probability of occurrence in practice.

By following the same procedure as in the first recommendation, the design force on a mechanical or electrical equipment can be required to satisfy

$$F_p = \frac{A_v a_x a_c P W_c}{R_s} \quad (4.1)$$

where

$$a_c = \begin{cases} 1, & \text{for rigidly-mounted equipment} \\ 2, & \text{for flexibly-mounted equipment} \end{cases} \quad (4.2)$$

which accounts for the tuning effect as well as the reduction effect due to potential component yielding. All the remaining factors in Eq. (4.1) are exactly the same as those in Eq. (3.1)

For the design of architectural components, coefficient a_c in Eq. (4.1) is simply assigned to be unity and the performance criteria factor (P) is taken from Table 3-3.

SECTION 5

THIRD RECOMMENDATION

In this approach, we consider equipment detailing such as specific anchorage design and constraints imposed by the supporting structure, possible ductility capacity in the equipment design, and the transient characteristics of input motion as having major contributions to the assignment of C_c . The supporting building structure effect on the design of mechanical and electrical equipment is considered to be implicitly covered in the determination of C_c values and will not be considered elsewhere in this approach. Therefore, the response modification coefficient (R_c), to be introduced below, is closely related to the C_c values from Tables 8.2.2 and 8.3.2a in [7] for architectural component and equipment design but its values are more uniform than the C_c values for the various components. This is due to the fact that other factors such as location effect on the design force have been sorted out from somewhat arbitrarily assigned C_c values.

5.1 Suggested Revision of the Design Force

5.1.1 Design Force Equation

Mechanical and Electrical Equipment. In this approach, it is proposed that mechanical and electrical equipment and systems be designed for seismic force determined in accordance with the following equation:

$$F_p = C_p W_c \quad (5.1)$$

where

$$C_p = \frac{A_v a_x a_c P}{R_c} \quad (5.2)$$

in which A_v , W_c , a_x and a_c are the same as in the first recommendation. The performance criteria factor (P) is the same as in the current provisions. The response modification coefficient (R_c) is directly transferred from the values of C_c in the current provisions which includes the effect that the supporting structure has on the performance of equipment although this effect is considered to be small. Both the performance criteria factor and the response modification coefficient are tabulated in Table 5-1.

Architectural Components. For architectural component design, the design force required can also be determined by Eq. (5.1) but the amplification factor (a_c) is assigned

to be 1.0. The response modification coefficient (R_c) and the performance criteria factor (P) are different from their values for mechanical and electrical components and systems as demonstrated in Table 5-2.

5.1.2 Development of the Design Force Equation

Floor and Equipment Acceleration Coefficients. Floor acceleration is considered to be linearly distributed along the structural height as shown in Fig. 3-1. The floor acceleration coefficient at h_x level is then denoted by $A_v a_x$ and the equipment acceleration coefficient at the same level can subsequently be expressed as $A_v a_x a_c$.

Inertia Force on Equipment. The inertia force acting on the equipment at h_x level can be written as

$$F_p = A_v a_x a_c W_c \quad (5.3)$$

Response Modification Coefficient. As in the design of building structures, the design force for the equipment can be reduced by a factor R_c , i.e.,

$$F_p = \frac{A_v a_x a_c W_c}{R_c} \quad (5.4)$$

due to earthquake variabilities and detailing construction of equipment including small amounts of allowable yielding in equipment anchorage and possible redundant constraint to the equipment.

Performance Criteria Factor. After the performance criteria factor has been considered, the design force on the equipment expressed in Eq. (5.4) becomes

$$F_p = \frac{A_v a_x a_c P W_c}{R_c} \quad (5.5)$$

5.1.3 Determination of Response Modification Coefficient (R_c)

As has been briefly discussed above, the value of R_c is related to the determination of the value of C_c in the current provisions but need to be modified subject to further investigations. In fact, R_c in this recommendation is close to the intermediate result (\bar{R}_c) of the first recommendation in deriving the response modification coefficient. In what follows, we simply compare a_x/R_c with C_c in the current provisions to determine the corresponding response modification coefficient (R_c). More specifically, we assign the minimum value of R_c to the most vulnerable components with maximum C_c values. For example, when a communication system is installed on the top floor of a building, the C_c value can be taken

from Table 8.3.2a of the current provisions as 2.0 and the amplification factor on the top floor (a_n) is considered to be 3.75. The response modification coefficient is therefore equal to $3.75/2.0 = 1.88$. All the R_c values for different mechanical and electrical equipment and architectural components are tabulated in Tables 5-1 and 5-2. For some nonstructural components, such as elevator shaft enclosures, stair enclosures, etc., which can span two or more floors in a building, the response modification coefficient R_c is considered to be the floor amplification factor a_x at 3/5 height divided by the corresponding C_c value. The 3/5 height approximately represents node of the second mode of the building structure and the corresponding response modification coefficient (R_c) implicitly accounts for the second mode contribution to the design force of nonstructural components attached to the upper 2/5-height floors of the building on the conservative side.

TABLE 5-1. Mechanical and Electrical Component and System Response Modification Coefficient (R_c) and Performance Criteria Factor (P)

| Mechanical and Electrical Component or System | Response Modification Coefficient (R_c) | Performance Criteria Factor (P) | | | |
|--|---|---------------------------------|-------------------|-------------------|-------|
| | | Seismic | Hazard | Exposure | Group |
| | | I | II | III | |
| Fire protection equipment and systems | 1.25 | 1.5 | 1.5 | 1.5 | |
| Emergency or standby electrical systems | 1.25 | 1.5 | 1.5 | 1.5 | |
| Elevator drive, suspension system, and control anchorage | 2.0 | 1.0 | 1.0 | 1.5 | |
| General equipment Boilers, furnaces, incinerators, water heaters, and other equipment using combustible energy sources or high temperature energy sources chimneys, flues, smokestacks, and vents Communication systems Electrical bus ducts, conduit, and cable trays Electrical motor control centers, motor control devices, switchgears, transformers, and unit substations Reciprocating or rotating equipment Tanks, heat exchangers, and pressure vessels Utility and service interfaces | 1.25 | 0.5 | 1.0 | 1.5 | |
| Manufacturing and process machinery | 4.0 | 0.5 | 1.0 | 1.5 | |
| Pipe systems Gas and high hazard piping Fire suppression piping Other pipe systems | 1.25 1.25 4.0 | 1.5 1.5 NR | 1.5 1.5 1.0 | 1.5 1.5 1.5 | |
| HVAC and service ducts | 4.0 | NR | 1.0 | 1.5 | |
| Electrical panel boards and dimmers | 4.0 | NR | 1.0 | 1.5 | |
| Lighting fixtures | 4.0 | 0.5 | 1.0 | 1.5 | |
| Conveyor systems (nonpersonnel) | 4.0 | NR | NR | 1.5 | |

TABLE 5-2. Architectural Component Response Modification Coefficient (R_c) and Performance Criteria Factor (P)

| Architectural Component | Response Modification Coefficient (R_c) | Performance Criteria Factor (P) | | | |
|---|---|---------------------------------|--------|----------|-------|
| | | Seismic | Hazard | Exposure | Group |
| | | I | II | III | |
| Exterior nonbearing walls | 3.0 | 1.5 | 1.5 | 1.5 | |
| Interior nonbearing walls | | | | | |
| Stair enclosures | 1.8 | 1.0 | 1.0 | 1.5 | |
| Elevator shaft enclosures | 1.8 | 0.5 | 0.5 | 1.5 | |
| Other vertical shaft enclosures | 3.0 | 1.0 | 1.0 | 1.5 | |
| Other nonbearing walls | 3.0 | 1.0 | 1.0 | 1.5 | |
| Cantilever elements | | | | | |
| Parapets, chimneys, or stacks | 1.0 | 1.5 | 1.5 | 1.5 | |
| Wall attachments (see Sec. 8.2.3) | 1.0 | 1.5 | 1.5 | 1.5 | |
| Veneer connections | 1.0 | 0.5 | 1.0 | 1.0 | |
| Penthouses | 4.5 | NR | 1.0 | 1.0 | |
| Structural fireproofing | 3.0 | 0.5 | 1.0 | 1.5 | |
| Ceilings | | | | | |
| Fire-rated membrane | 3.0 | 1.0 | 1.0 | 1.5 | |
| Nonfire-rated membrane | 4.5 | 0.5 | 1.0 | 1.0 | |
| Storage racks more than 8 feet in height (content included) | 1.8 | 1.0 | 1.0 | 1.5 | |
| Access floors (supported equipment included) | 1.25 | 0.5 | 1.0 | 1.5 | |
| Elevator and counterweight guiderails and supports | 2.0 | 1.0 | 1.0 | 1.5 | |
| Appendages | | | | | |
| Roofing units | 4.5 | NR | 1.0 | 1.0 | |
| Containers and miscellaneous components (free standing) | 1.8 | NR | 1.0 | 1.0 | |
| Partitions | | | | | |
| Horizontal exits including ceilings | 3.0 | 1.0 | 1.5 | 1.5 | |
| Public corridors | 3.0 | 0.5 | 1.0 | 1.5 | |
| Private corridors | 4.5 | NR | 0.5 | 1.5 | |
| Full height area separation partitions | 3.0 | 1.0 | 1.0 | 1.5 | |
| Full height other partitions | 4.5 | 0.5 | 0.5 | 1.5 | |
| Partial height partitions | 4.5 | NR | 0.5 | 1.0 | |

SECTION 6

COMPARISON OF DESIGN FORCES

In this section, two architectural components (parapet and storage rack) and one mechanical or electrical equipment are chosen to demonstrate that the recommended approaches overcome much of the shortcomings in the current provisions as discussed in Section 2.2. They are also used to compare the relative conservativeness of various provisions and design codes. All the comparisons are made based on the determination of the seismic design coefficient for components (C_p) as a function of structural period (T_s).

6.1 Maximum and Minimum Design Forces

It is instructive to make a simple comparison among maximum and minimum design forces specified in different provisions and codes. The maximum and minimum design forces of nonstructural components among three recommended provisions are compared in Table 6-1 and those of the 1991 NEHRP, the 1991 UBC, and the 1985 Tri-Service codes are tabulated in Table 6-2. It can be observed that the recommended force formulas yield maximum forces which are higher than those specified in the UBC and the current NEHRP provisions but are less than those given in the Tri-Service Code. On the other hand, the minimum design forces are consistently less than the values specified in the other provisions and codes. These larger variations in the design force exist since more factors such as soil property, equipment location, and supporting structural characteristics have been taken into account in the recommended formulas, which is a major contribution of the suggested formulation for nonstructural element design. In addition, these extreme forces can not be reached in most cases of practical design because the combination of all the factors contributing to the extreme values hardly occurs in practice.

6.2 Case Studies (Parapets, Storage Racks and General Equipment on Reinforced Concrete Shear Walls)

6.2.1 Effects of Soil Type, Structural Period and Component Location

It is instructive to know how significant the effects of the soil condition, structural period, and component location on nonstructural component design are before comparing design forces of the three recommended approaches with those of current available provisions and codes.

The parapet chosen here is considered to be atop a building structure. The storage rack and mechanical or electrical equipment are considered to be installed either at the top floor or at the middle floor of the building. The parameters used in these case studies are given in Table 6-3.

The seismic design coefficients (C_p) for a parapet determined by the three recommended revisions are presented in Fig. 6-1. It can be seen that C_p is a function of structural period and the soil type. As the building structure becomes more flexible or the soil layer under the structure becomes stiffer, the design force on the parapet decreases.

Figures 6-2, 6-3 and 6-4 present the seismic design coefficients determined by the three recommended approaches for a storage rack installed at the top or middle of the building. As one can see from these plots, the storage rack location in the building has a significant influence on the seismic design force imposed on it. The higher the storage rack location, the larger the required design force. When the storage rack is anchored to the very flexible building structure, the location effect on the design force becomes less significant, since the floor amplification factor (a_x) approaches unity in the limit. As in the case of parapet design, similar effects of structural period and soil type on the design force for the storage rack can be observed.

For seismic design of the mechanical or electrical equipment, the seismic design coefficients determined in accordance with the first recommended revision are respectively shown in Figs. 6-5(a,b) when it is installed at the top and middle of a building structure; those with the second recommended revision are shown in Figs. 6-6(a,b); and those with the third recommended revision are shown in Figs. 6-7(a,b), respectively. An examination of these figures indicates that the tuning effect on the design force is significant and effects of structural period, soil type and equipment location on the design forces are consistent with those found for the parapet and storage rack designs.

6.2.2 Comparisons Among the Three Recommendations

Comparisons among the three recommended revisions may shed more light on their relative merits toward improvement over the 1991 NEHRP provisions. The seismic design coefficients for the parapet, the storage rack, and the mechanical or electrical equipment are presented in Figs. 6-1, 6-8 and 6-9. It can be observed from Figs. 6-1 and 6-9 for the parapet and equipment design that the seismic design coefficient determined by the third recommendation is the highest while the corresponding value produced by the second recommendation is the smallest. This mainly results from the reduction effect

due to structural yielding in these examples, i.e., $R_s = 1.5$. In contrast, the second recommendation provides a larger design force for the storage rack design since the response modification coefficient of the structure for the storage rack design ($R_s = 1.5$) is smaller than that of the component ($R_c = 1.8$). It should be noted that the seismic design coefficient calculated by the first recommendation may be larger in other cases than those of the remaining two recommendations. In other words, comparisons among the three recommendations can only be made on individual cases. Anyone of them can produce the most or least conservative design force for a given nonstructural component.

6.2.3 Recommended Revisions vs. U.S. Codes/Provisions

As can be seen from Fig. 6-1, the first and second recommended revisions provide smaller design forces than that given by the 1991 NEHRP provisions for design of the parapet atop a building structure with various flexibility while the third revision requires a larger design force for the same parapet attached to a stiff building structure and a smaller design force to a flexible building than that required by the current NEHRP provisions. Compared with the 1991 UBC or the 1985 Tri-Service Code, the recommended revisions require larger seismic design forces in a broad range of structural periods.

The seismic design coefficients for the storage rack calculated from the recommended revisions are compared in Figs. 6-2, 6-3 and 6-4 with the 1991 NEHRP provisions, the 1991 UBC and 1985 Tri-Service codes when it is installed at the top or middle of a building structure. The seismic design coefficients for the storage rack attached to the top floor, calculated by the recommended formulas, are greater in the case of a stiff building and smaller in the case of a flexible building than the corresponding coefficient provided in the current NEHRP provisions. The second recommended revision requires a slightly greater seismic design force for the storage rack design than that given by the 1991 UBC for the middle attachment as in the case of top attachment; whereas the first and third recommended revisions require smaller seismic design forces than the current NEHRP values but larger design forces than the 1991 UBC or the 1985 Tri-Service values when the storage rack is supported by a stiff building.

The seismic design coefficients of the mechanical or electrical equipment installed at the top of a building, calculated by the recommended revisions, are compared in Figs. 6-5(a), 6-6(a), 6-7(a) and 6-9 with those specified in the current NEHRP provisions, UBC and Tri-Service codes. In the tuned case, as shown in Fig. 6-9, the seismic design coefficients from the suggested approaches are larger for stiff building structures and

smaller for flexible building structures than the corresponding values provided by the 1991 NEHRP and the 1985 Tri-Service codes but consistently larger than the design coefficient given by the 1991 UBC code. In the detuned case as shown in Figs. 6-5(a), 6-6(a) and 6-7(a), the recommended seismic design coefficients are also larger for a stiff structure and smaller for a flexible structure than the 1991 NEHRP values, but those provided by the second and third recommendations are consistently larger than the 1991 UBC and the 1985 Tri-Service values.

It is worth noting that, for a nonstructural component attached to a very flexible structure, the recommended design forces are in many cases smaller than those provided by the 1991 UBC and the 1985 Tri-Service codes. This seems contradictory to the design philosophies employed in the NEHRP provisions and UBC (or Tri-Service) Code (strength design vs. stress design). In fact, this phenomenon only indicates the over conservativeness involved in the UBC and Tri-Service codes for this case since the recommended revisions in this report are justified to a certain degree by analyses, experimental results and observation data from past earthquakes.

TABLE 6-1. Maximum and Minimum Design Forces (1)

| | first recommendation | | second recommendation | | third recommendation | |
|----------------|--|---|---|--|---|--|
| Design Code | Architectural | Mechanical & Electrical | Architectural | Mechanical & Electrical | Architectural | Mechanical & Electrical |
| Basic Equation | $F_p = \frac{A_v a_x P W_c}{R_s R_c}$ | $F_p = \frac{A_v a_x a_c P W_c}{R_s R_c}$ | $F_p = \frac{A_v a_x P W_c}{R_s}$ | $F_p = \frac{A_v a_x a_c P W_c}{R_s}$ | $F_p = \frac{A_v a_x P W_c}{R_c}$ | $F_p = \frac{A_v a_x a_c P W_c}{R_c}$ |
| Basis | Strength Design | Strength Design | Strength Design | Strength Design | Strength Design | Strength Design |
| Maximum Value | $\frac{0.4 \times 3.75 \times 1.2 W_c}{1.0 \times 1.0}$ $= 1.80 W_c$ | $\frac{0.4 \times 3.75 \times 2.5 \times 1.2 W_c}{1.0 \times 1.1}$ $= 4.09 W_c$ | $\frac{0.4 \times 3.75 \times 1.2 W_c}{1.0}$ $= 1.80 W_c$ | $\frac{0.4 \times 3.75 \times 2.0 \times 1.2 W_c}{1.0}$ $= 3.60 W_c$ | $\frac{0.4 \times 3.75 \times 1.5 W_c}{1.0}$ $= 2.25 W_c$ | $\frac{0.4 \times 3.75 \times 2.5 \times 1.5 W_c}{1.25}$ $= 4.50 W_c$ |
| Minimum Value | $\frac{0.05 \times 1.0 \times 0.8 W_c}{2.0 \times 3.0}$ $= 0.007 W_c$ | $\frac{0.05 \times 1.0 \times 1.0 \times 0.8 W_c}{2.0 \times 2.7}$ $= 0.007 W_c$ | $\frac{0.05 \times 1.0 \times 0.8 W_c}{2.0}$ $= 0.020 W_c$ | $\frac{0.05 \times 1.0 \times 1.0 \times 0.8 W_c}{2.0}$ $= 0.020 W_c$ | $\frac{0.05 \times 1.0 \times 0.5 W_c}{4.5}$ $= 0.006 W_c$ | $\frac{0.05 \times 1.0 \times 1.0 \times 0.5 W_c}{4.0}$ $= 0.006 W_c$ |

TABLE 6-2. Maximum and Minimum Design Forces (2)

| | 1991 NEHRP | | 1991 UBC | 1985 Tri-Service | |
|----------------|---|---|---|---|--|
| Design Code | Architectural | Mechanical & Electrical | Nonstructural | Architectural | Mechanical & Electrical |
| Basic Equation | $F_p = A_v C_p P W_c$ | $F_p = A_v C_p P a_c W_c$ | $F_p = Z I C_p W_p$ | $F_p = Z I C_p W_p$ | $F_p = Z I A_p C_p W$ |
| Basis | Strength Design | Strength Design | Allowable Stress | Allowable Stress | Allowable Stress |
| Maximum Value | $0.4 \times 3.0 \times 1.5 W_c$ $= 1.80 W_c$ | $0.4 \times 2.0 \times 1.5 \times 2.0 W_c$ $= 2.40 W_c$ | $0.4 \times 1.5 \times 2.0 W_p$ $= 1.20 W_p$ | $1.0 \times 1.5 \times 0.8 W_p$ $= 1.20 W_p$ | $1.0 \times 1.5 \times 5.0 \times 0.8 W_p$ $= 6.00 W_p$ |
| Minimum Value | $0.05 \times 0.6 \times 0.5 W_c$ $= 0.015 W_c$ | $0.05 \times 0.67 \times 0.5 \times 1 W_c$ $= 0.017 W_c$ | $\frac{2}{3} \times 0.05 \times 1.0 \times 0.75 W_p$ $= 0.025 W_p$ | $\frac{3}{16} \times 1.0 \times 0.3 W_p$ $= 0.056 W_p$ | $\frac{3}{16} \times 1.0 \times 1.0 \times 0.3 W_p$ $= 0.056 W_p$ |

TABLE 6-3. Parameters Used in Case Studies

| Provisions/Codes | Parapet ($a_c=A_p=1.0$) | Storage Rack ($a_c=A_p=1.0$, $P=I=1.0$) | Equipment ($P=I=1.0$) (a_c =detuned/ tuned) |
|-----------------------|--|---|--|
| first Recommendation | $A_v=0.2$, $P=1.2$, $R_s=1.5$, $R_c=1.0$ | $A_v=0.2$, $R_s=1.5$, $R_c=1.5$ | $A_v=0.2$, $R_s=1.5$, $R_c=1.1$, $a_c=1.0/2.5$ |
| second recommendation | $A_v=0.2$, $P=1.2$, $R_s=1.5$ | $A_v=0.2$, $R_s=1.5$ | $A_v=0.2$, $R_s=1.5$, $a_c=1.0/2.0$ |
| third Recommendation | $A_v=0.2$, $P=1.5$, $R_c=1.0$ | $A_v=0.2$, $R_c=1.8$ | $A_v=0.2$, $R_c=1.25$, $a_c=1.0/2.5$ |
| 1991 NEHRP | $A_v=0.2$, $P=1.5$, $C_c=3.0$ | $A_v=0.2$, $C_c=1.5$ | $A_v=0.2$, $C_c=2.0$, $a_c=1.0/2.0$ |
| 1991 UBC | $Z=0.2$, $I=1.25$, $C_p=2.0$ | $Z=0.2$, $C_p=0.75$ | $Z=0.2$, $C_p=0.75$ |
| 1985 Tri-Service | $Z=0.5$, $I=1.25$, $C_p=0.8$ | $Z=0.5$, $C_p=0.3$ | $Z=0.5$, $C_p=0.3$, $A_p=1.0/5.0$ |




Fig. 6-1 Seismic Design Coefficient for Parapet at Top of Building




Fig. 6-2 Seismic Design Coefficient for Storage Rack at Different Locations
(First Recommendation)




Fig. 6-3 Seismic Design Coefficient for Storage Rack at Different Locations
(Second Recommendation)




Fig. 6-4 Seismic Design Coefficient for Storage Rack at Different Locations (Third Recommendation)




Fig. 6-5(a) Seismic Design Coefficient of Equipment at Top of Building
(First Recommendation)




Fig. 6-5(b) Seismic Design Coefficient of Equipment at Middle of Building
(First Recommendation)




Fig. 6-6(a) Seismic Design Coefficient of Equipment at Top of Building
(Second Recommendation)




Fig. 6-6(b) Seismic Design Coefficient of Equipment at Middle of Building
(Second Recommendation)




Fig. 6-7(a) Seismic Design Coefficient of Equipment at Top of Building
(Third Recommendation)




Fig. 6-7(b) Seismic Design Coefficient of Equipment at Middle of Building
(Third Recommendation)




Fig. 6-8 Seismic Design Coefficient for Storage Rack at Top of Building




Fig. 6-9 Seismic Design Coefficient of Equipment at Top (Tuned Case)

SECTION 7

DESIGN DISPLACEMENT

There are three types of displacements involved in the design of mechanical and electrical equipment, i.e., flexible support deformation, sliding displacement and interstory distortion. The flexible support deformation is defined as the relative displacement of the equipment with respect to its attached floor. The sliding displacement of an equipment with low center of gravity occurs when bolts (if exist) connecting the equipment anchorage to the building floor are damaged or when the maximum friction force between the equipment and floor (no bolts) is exceeded. The interstory distortion of one building structure or between two adjacent buildings is relevant to the design of equipment such as piping systems installed over two or more floors of the building structure or between two building structures.

For seismic design of architectural components, only interstory distortion is of interest.

7.1 Flexible Support Deformation

In order to suppress vibrational levels of a mechanical or electrical equipment, flexible anchorage of the equipment is generally required. When flexibility of the equipment anchorage is relatively large, the design force on the equipment may not be critical. However, the relative displacement of the equipment with respect to its attached floor may exceed an allowable level, which will also cause anchorage damage. In addition, when anchorage ductility is taken into account as in the first and third recommendations, the design force on the equipment would also be small. Nevertheless, the inelastic deformation in this case may be excessive. For these reasons, a displacement equation for flexibly-supported equipment which provides support deformation information is of practical value.

7.1.1 Displacement Equation

From Eq. (3.1), the relative displacement of an equipment with respect to its supporting floor can be formulated as

$$\Delta_p = \frac{F_p}{K_c} = \frac{A_v a_x a_c P g T_c^2}{4\pi^2 R_s R_c} \quad (7.1)$$

in which g is the gravitational acceleration. The response modification coefficient (R_c) should be assigned to be 1.0 to obtain the maximum displacement.

7.1.2 Example: A General Equipment

The same type of general equipment as in Section 6 is used here to show the magnitude of its relative displacement with respect to the floor. The calculated displacements for different equipment periods are presented in Table 7-1. As one can observe, the relative displacement increases as the anchorage becomes flexible.

7.2 Sliding Displacement

As indicated in the brief introduction of this section, sliding of a rigid body which is not bolted to the floor occurs when seismic load acting on the rigid body exceeds friction force between the rigid body and its supporting floor. Sliding of a general equipment which is bolted to the floor could also occur when bolts fail when the seismic load is excessive.

It is noted that only equipment with low centers of gravity are considered here so that the possibility of overturning of the equipment is ignored.

7.2.1 Displacement Equation

The sliding distance of a rigid body along its supporting building floor can be approximately determined in accordance with

$$\Delta_p = C_\delta \delta_s \quad (7.2)$$

in which δ_s is the relative displacement of the building floor with respect to ground and can be determined from the building structural analysis exclusively. The sliding coefficient C_δ can be calculated from

$$C_\delta = \left| \frac{\eta \gamma^2}{2} - \frac{1 - \cos \gamma}{\eta} \right| \quad (7.3)$$

where

$$\gamma = \frac{2\pi(t_3 - t_1)}{T_s} \quad (7.4)$$

and satisfies the following equation:

$$\gamma = \frac{\sqrt{1 - \eta^2}(1 - \cos \gamma)}{\eta} + \sin \gamma \quad (7.5)$$

Here, $t_3 - t_1$ represents the time interval during which the rigid body moves within a half cycle of seismic input from the building floor. The parameter η represents the relative strength of resistance (friction force) and load (seismic force) which can be simply expressed as

$$\eta = \frac{\mu(1 - a_v)}{A_v a_x} \quad (7.6)$$

in which μ is the friction coefficient between the rigid body and its supporting floor, and a_v represents vertical acceleration of the supporting floor that is approximately equal to $A_v/3$ if floor amplification effect of the vertical acceleration is insignificant.

7.2.2 Development of the Displacement Equation

For the purpose of developing a simple sliding distance equation, the absolute acceleration of a building floor to which a mechanical or electrical equipment is attached can be simply considered as a harmonic motion with the fundamental period of the building structure. In the case of a mechanical or electrical equipment installed on the upper floors of a building structure, which is usually of practical interest, the contribution of the first mode of the structure to the seismic response of the equipment is predominant and therefore accelerations of the upper floors appear to be harmonic, i.e.,

$$\ddot{x}_f(t) = A_v a_x g \sin\left(\frac{2\pi t}{T_s}\right) \quad (7.7)$$

The rigid body begins to slide when the inertia force $m_c \ddot{x}_f(t)$ acting on it exceeds the effective friction force and it stops again when $m_c \ddot{x}_f(t)$ is less than the friction force as shown in Fig. 7-1. The rigid body will move back and forth along a perfectly horizontal building floor during earthquakes and only a half cycle of seismic excitation $\ddot{x}_f(t)$ is needed to obtain maximum sliding distance of the rigid body.

The equation of motion of the rigid body ($W_c = m_c g$) can be written as

$$\ddot{z}(t) = \begin{cases} 0, & m_c \ddot{x}_f(t) < F_f \\ \frac{F'_f}{m_c} - \ddot{x}_f(t), & m_c \ddot{x}_f(t) \geq F_f \end{cases} \quad (7.8)$$

in which $z(t)$ denotes the sliding displacement of the rigid body, and F_f and F'_f are static and dynamic friction forces, respectively. The dynamic friction force (F'_f) is considered to be approximately equal to the static friction (F_f) for simplicity. Both of them can be represented by

$$F'_f = F_f = \mu m_c g (1 - a_v) \quad (7.9)$$

The initial conditions for sliding of the rigid body can be expressed as

$$z(t) = \dot{z}(t) = 0 \quad (7.10)$$

By substituting Eq. (7.9) for F'_f in Eq. (7.8), the equation of motion can be rewritten as

$$\ddot{z}(t) = \mu g (1 - a_v) - A_v a_x g \sin\left(\frac{2\pi t}{T_s}\right) \quad (t_1 \leq t \leq t_3) \quad (7.11)$$

with the solution of

$$\dot{z}(t) = \mu g(1 - a_v)(t - t_1) + \frac{T_s}{2\pi} A_v a_x g \left(\cos \frac{2\pi t}{T_s} - \cos \frac{2\pi t_1}{T_s} \right) \quad (7.12)$$

$$z(t) = 0.5\mu g(1 - a_v)(t - t_1)^2 + \frac{T_s}{2\pi} A_v a_x g \left[\frac{T_s}{2\pi} \left(\sin \frac{2\pi t}{T_s} - \sin \frac{2\pi t_1}{T_s} \right) - (t - t_1) \cos \frac{2\pi t_1}{T_s} \right] \quad (7.13)$$

To determine the starting and ending time instants (t_1 and t_3), the following conditions are introduced:

$$\ddot{z}(t_1) = 0 \quad (7.14)$$

$$\dot{z}(t_3) = 0 \quad (7.15)$$

Solving these two equations simultaneously yields Eq. (7.5). The maximum sliding distance can then be calculated by

$$\Delta_p = |z(t_3)| = \frac{A_v a_x g T_s^2}{4\pi^2} C_\delta = C_\delta \delta_s \quad (7.16)$$

The values of C_δ for different values of the parameter η in Eq. (7.6) are tabulated in Table 7-2.

7.3 Interstory Distortion

An architectural component such as a wall system is often subjected to distortion action due to story drift of its supporting building structure. A piping system inside a building structure is also restrained by story drift and a piping system attached to two adjacent buildings may be subjected to their differential movement. Therefore, interstory distortions inside a building structure or between two adjacent buildings are important to the design of this type of nonstructural components. However, constraint displacements of this type for nonstructural components can be exclusively calculated from structural analysis when the nonstructural components are considered to be relatively light. For this reason, explicit expressions for these interstory distortions are not discussed here.

**TABLE 7-1. Displacement of Flexibly-Mounted Equipment at Top of Building
(Soil Type I)**

| T_s (seconds) | | 0.0 | 0.33 | 0.44 | 0.61 | 0.94 |
|---|-----------------------|-----|--------|--------|--------|--------|
| Tuned $T_c = T_s$ | first recommendation | 0.0 | 0.034 | 0.050 | 0.077 | 0.137 |
| | second recommendation | 0.0 | 0.037 | 0.054 | 0.084 | 0.149 |
| | third recommendation | 0.0 | 0.051 | 0.075 | 0.115 | 0.201 |
| Detuned $T_c < 0.5 T_s$ or $T_c > 2.0 T_s$ | first recommendation | 0.0 | 0.0034 | 0.0050 | 0.0077 | 0.0137 |
| | second recommendation | 0.0 | 0.0046 | 0.0067 | 0.0105 | 0.0186 |
| | third recommendation | 0.0 | 0.0051 | 0.0075 | 0.0115 | 0.0201 |
| R_c in the first and third recommendations are taken as 1.0 for displacement determination to obtain the maximum elastic deformation presented above. | | | | | | |

TABLE 7-2. Sliding Coefficient

| | | | | | | | |
|--------------|--------|--------|--------|--------|--------|--------|-----|
| η | 0.4 | 0.5 | 0.6 | 0.7 | 0.8 | 0.9 | 1.0 |
| C_{δ} | 1.8780 | 1.2658 | 0.7884 | 0.4325 | 0.1878 | 0.0460 | 0.0 |




Fig. 7-1 Sliding Displacement

SECTION 8

CONCLUDING REMARKS

Three approaches to the modification of the 1991 NEHRP design force equations for nonstructural components have been developed by incorporating different levels of consideration for structural and component effects. In the first recommendation, structural and component characteristics are jointly taken into account, which is no doubt the most comprehensive. The second recommendation is basically a structure-driven type modification to the current provisions. The third recommendation mainly concerns the effect of different types of components on the force, representing the least modified version.

Design force equations recommended in this report preserve the equivalent lateral force concept, a static procedure in which all the dynamic characteristics such as modal contribution, damping ratio, and response spectrum are not explicitly included. However, these statics-based equations can be justified based on dynamic analysis of the first mode representation of MDOF systems with 5% modal damping following the cascade (decoupled) procedure.

The values of the component response modification coefficient (R_c) in this report are basically transferred from those of the seismic coefficient (C_c) of the current provisions. They are subjected to further modification by practitioners.

An attempt was made to consider the structural yielding effect on the acceleration or inertia force distribution along building height. In general, the larger the structural inelastic deformation or the larger the seismic input, the more uniform the distribution of the maximum acceleration along the building height. However, it was decided in this revision to ignore the structural yielding effect on the acceleration distribution due to simplicity requirements for practical design and insufficient observed data for statistical analysis.

Overall, the recommended modifications of the 1991 NEHRP design force equations for nonstructural components represent a major effort which, on the one hand, preserves the equivalent lateral force format for practical applicability and, on the other, identifies and corrects deficiencies in the current provisions to the extent feasible. It has been shown that these recommended revisions can be justified on the basis of analyses, experimental

results, and observation data from past earthquakes; and they represent a significant improvement over the 1991 NEHRP design force formulas.

Current provisions do not include design guidelines based on displacements or deformations on the part of nonstructural components. Since excessive displacements or movements are causes of a significant number of past nonstructural failures, simple equations have also been presented which can be used to estimate flexible support deformation and the amount of sliding a nonstructural component can experience during a seismic event. The inclusion of this type of displacement equations in future codes and provisions is recommended.

SECTION 9

REFERENCES

1. ASCE Working Group on Qualification of Uncertainties, 1986. *Uncertainty and Conservatism in the Seismic Analysis and Design of Nuclear Facilities*. American Society of Civil Engineers, New York, NY.
2. Ayres, J. Marx, Sun, Tseng-Yao and Brown, Frederick R., 1973. "Nonstructural Damage to Buildings," *The Great Alaska Earthquake of 1964: Engineering*, National Academy of Sciences, Washington, D.C.
3. Ayres, J. Marx and Sun, Tseng-Yao, 1973. "Nonstructural Damage," *The San Fernando California Earthquake of February 9, 1971*, Washington, D.C.: National Oceanic and Atmospheric Administration.
4. Aziz, T.S. and Ghobarah, A. 1988. "Equipment Seismic Design: Future Directions," *Proceedings of 9th World Conference on Earthquake Engineering*, Vol. VI, August 2-9, Tokyo-Kyoto, Japan, 261-266.
5. Building Seismic Safety Council, 1985. "NEHRP Recommended Provisions for the Development of Seismic Regulations for New Buildings: Part 1: Provisions and Part 2: Commentary."
6. Building Seismic Safety Council, 1988. "NEHRP Recommended Provisions for the Development of Seismic Regulations for New Buildings: Part 1: Provisions and Part 2: Commentary."
7. Building Seismic Safety Council, 1991. "NEHRP Recommended Provisions for the Development of Seismic Regulations for New Buildings: Part I: Provisions and Part 2: Commentary."
8. Chen, Genda, 1992. "Power Flow and Energy in Primary-Secondary Structural Systems under Earthquake Loads," *Ph.D. Dissertation*, State University of New York at Buffalo, Buffalo, NY.
9. Chen, Y.Q. and Soong, T.T., 1988. "State-of-the-art Review: Seismic Response of Secondary Systems," *Engineering Structure*, 10, 218-228.

10. Hiramatsu, K., Sato, Y., Akagi, H. and Tomita, S., 1988. "Seismic Response Observation of Building Appendage," *Proceedings of 9th World Conference on Earthquake Engineering*, Tokyo-Kyoto, Japan, 6, 237-243.
11. Hirosaw, M., Mizuno, H. and Midorikawa, M., 1992. "State-of-the-art Report on Seismic Design of Building Equipment and Nonstructural Components in Japan," *BRI Research Paper No. 137*, Building Research Institute, Ministry of Construction.
12. Housner, G.W. and Jennings, P.C., 1964. "Generation of Artificial Earthquakes," *ASCE, EM*, 90(1), 113-142.
13. International Conference of Building Officials, 1991. *Uniform Building Code*, Whittier, CA.
14. Juhn, G., Manolis, G.D. and Reinhorn, A.M., 1990. "Experimental Analysis and Floor Response Spectra for Secondary Systems in a Fixed-based Frame," *ATC-29 Seminar: Seismic Design and Performance of Equipment and Nonstructural Elements in Buildings and Industrial Structures*, Irvine, CA.
15. Kelly, J.M., 1982. "The Influence of Base Isolation on the Seismic Response of Light Secondary Equipment," *Report No. UCB/EERC-81/17*, Earthquake Engineering Research Center, University of California, Berkeley, CA.
16. Kelly, J.M. and Tsai, H.C., 1985. "Seismic Response of Light Internal Equipment in Base-Isolated Structures," *Earthquake Engineering and Structural Dynamics*, 13, 711-732.
17. Lin, J. and Mahin, S.A. 1985. "Seismic Response of Light Subsystems on Inelastic Structures," *ASCE, ST*, 111(2), 400-417.
18. Manolis, G.D., Juhn, G. and Reinhorn, A.M., 1988. "Experimental Investigation of Primary-Secondary Interaction," *Report NCEER-88-0019*, National Center for Earthquake Engineering Research, Buffalo, NY.
19. Pires, J.A., 1990. "Analysis of Nonlinear Primary-Secondary Systems under Random Seismic Loading," *Proceedings of Fourth U.S. National Conference on Earthquake Engineering*, Vol. 3, May 20-24, Palm Springs, CA, 51-60.
20. Porush, A.R., 1990. "An Overview of the Current Building Code Seismic Requirements for Nonstructural Elements," *ATC-29 Seminar: Seismic Design and Performance of*

Equipment and Nonstructural Elements in Buildings and Industrial Structures, Irvine, CA.

21. Sato, Y., Fuse, T. and Akagi, H., 1984. "Building Appendage Seismic Design Force Based on Observed Floor Response," *Proceedings of the 8th World Conference on Earthquake Engineering*, San Francisco, CA, 5, 1167-1174.
22. Singh, M.P., 1990. "An Overview of Techniques for Analysis of Non-Structural Components," *ATC-29 Seminar: Seismic Design and Performance of Equipment and Nonstructural Elements in Buildings and Industrial Structures*, Irvine, CA.
23. Soong, T.T., 1989. "Stochastic Structural Dynamics: Research vs. Practice," *Structural Safety*, 6, 129-134.
24. State of California, 1976. "General Building Regulations," *California Administrative Code*, Title 24, Chapter 2 of Part I, Division T-17, Part 6. Sacramento, CA.
25. U.S. Departments of the Army, the Navy and the Air Force, 1985. *Seismic Design for Building*, Tri-Service Manual, Washington, D.C.
26. Whitman, R.V., 1992. "Proceedings from the Site Effects Workshop," *Report NCEER-92-0006*, National Center for Earthquake Engineering Research, Buffalo, NY.

APPENDIX

OBSERVATION DATA FROM SELECTED PAST EARTHQUAKES

Table A.1. Observation Data from Past Earthquakes

| Building Name | Hollywood Storage Building | | Hollywood Storage Building | |
|-------------------------------|------------------------------|------------------------------|-----------------------------------|-----------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. frame 14/149.5' | R.C. frame 14/149.5' | R.C. frame 14/149.5' | R.C. frame 14/149.5' |
| Period (sec.) | 1.86 | 0.64 | 1.86 | 0.64 |
| Soil Conditions | Pile Foundation | Pile Foundation | Pile Foundation | Pile Foundation |
| Earthquake | Kern County July 21, 1952 | Kern County July 21, 1952 | Whitter Narrows October1, 1987 | Whitter Narrows October1, 1987 |
| Magnitude (M_L) | 7.2 | 7.2 | 5.9 | 5.9 |
| E. C. D (km) | 122 | 122 | 25 | 25 |
| Acc. at Base (g's) | 0.06 | 0.04 | 0.11 | 0.06 |
| Acc. at Top (g's) | 0.12 | 0.15 | 0.20 | 0.19 |
| Amplification Factor | 2.00 | 3.75 | 1.82 | 3.17 |

Table A.1. (continued)

| Building Name | Hollywood Storage Building | | Santa Clara County Office | |
|-------------------------------|-----------------------------------|-----------------------------------|-------------------------------|-------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. frame 14/149.5' | R.C. frame 14/149.5' | Steel frame 13/186'7" | Steel frame 13/186'7" |
| Period (sec.) | 1.86 | 0.64 | 2.05 | 2.16 |
| Soil Conditions | Pile Foundation | Pile Foundation | ----- | ----- |
| Earthquake | Whitter Narrows October4, 1987 | Whitter Narrows October4, 1987 | Morgan Hill April 24, 1984 | Morgan Hill April 24, 1984 |
| Magnitude (M_L) | 5.3 | 5.3 | 6.2 | 6.2 |
| E. C. D (km) | 25 | 25 | 20 | 20 |
| Acc. at Base (g's) | 0.06 | 0.03 | 0.03 | 0.04 |
| Acc. at Top (g's) | 0.11 | 0.08 | 0.17 | 0.18 |
| Amplification Factor | 1.83 | 2.67 | 5.67 | 4.50 |

Table A.1. (continued)

| Building Name | Town Park Towers | | Great Western S & L Building | |
|-------------------------------|----------------------------|----------------------------|------------------------------|----------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. shear wall 10/95' | R.C. shear wall 10/95 | R.C. frame 10/124' | R.C. shear wall 10/124' |
| Period (sec.) | _____ | _____ | _____ | _____ |
| Soil Conditions | _____ | _____ | _____ | _____ |
| Earthquake | Morgan Hill April 24, 1984 | Morgan Hill April 24, 1984 | Morgan Hill April 24, 1984 | Morgan Hill April 24, 1984 |
| Magnitude (M_L) | 6.2 | 6.2 | 6.2 | 6.2 |
| E. C. D (km) | 20 | 20 | 20 | 20 |
| Acc. at Base (g's) | 0.06 | 0.06 | 0.06 | 0.06 |
| Acc. at Top (g's) | 0.22 | 0.14 | 0.18 | 0.22 |
| Amplification Factor | 3.67 | 2.33 | 3.00 | 3.67 |

Table A.1. (continued)

| Building Name | Building 180 JPL, CalTech | | Bank of California | |
|-------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 9/146' | Steel Frame 9/146' | R.C. Frame 12/174' | R.C. Frame 12/174' |
| Period (sec.) | 1.33 | 1.05 | 1.41 | 2.52 |
| Soil Conditions | — | — | — | — |
| Earthquake | San Fernando February 9,1971 | San Fernando February 9,1971 | San Fernando February 9,1971 | San Fernando February 9,1971 |
| Magnitude (M_L) | 6.5 | 6.5 | 6.5 | 6.5 |
| E. C. D (km) | 24 | 24 | 22.5 | 22.5 |
| Acc. at Base (g's) | 0.14 | 0.21 | 0.22 | 0.15 |
| Acc. at Top (g's) | 0.210 | 0.38 | 0.29 | 0.20 |
| Amplification Factor | 1.50 | 1.81 | 1.32 | 1.33 |

Table A.1. (continued)

| Building Name | Imperial County | Service Building | Freitas Building (Santa Babara) | |
|-------------------------------|------------------------------------|------------------------------------|----------------------------------|----------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. frame 6/81.5' | R.C. wall 6/81.5' | R.C Shear wall 4/53' | R.C. Shear wall 4/53' |
| Period (sec.) | 0.44-0.61 | 0.64-1.25 | 0.5 | —— |
| Soil Conditions | —— | —— | —— | —— |
| Earthquake | Imperial Valley October 15,1979 | Imperial Valley October 15,1979 | Santa Barbara August 13, 1978 | Santa Barbara August 13, 1978 |
| Magnitude (M_L) | 6.6 | 6.6 | 5.1-5.7 | 5.1-5.7 |
| E. C. D (km) | | | 20 | ----- |
| Acc. at Base (g's) | 0.29 | 0.33 | 0.23 | ----- |
| Acc. at Top (g's) | 0.58 | 0.45 | 0.55 | ----- |
| Amplification Factor | 2.00 | 1.36 | 2.39 | —— |

Table A.1. (continued)

| Building Name | Kajima Int. Building | | Holiday Inn | |
|-------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 15/208.5' | Steel Frame 15/208.5'' | R.C. Frame 7/66' | R.C. Frame 7/66' |
| Period (sec.) | 2.9 | 2.9 | 1.6 | 1.8 |
| Soil Conditions | — | — | — | — |
| Earthquake | San Fernando February 9,1971 | San Fernando February 9,1971 | San Fernando February 9,1971 | San Fernando February 9,1971 |
| Magnitude (M_L) | 6.5 | 6.5 | 6.5 | 6.5 |
| E. C. D (km) | 33.6 | 33.6 | 13 | 13 |
| Acc. at Base (g's) | 0.10 | 0.12 | 0.25 | 0.134 |
| Acc. at Top (g's) | 0.166 | 0.162 | 0.382 | 0.32 |
| Amplification Factor | 1.66 | 1.30 | 1.50 | 2.40 |

Table A.1. (continued)

| Building Name | Millikan Library | | Watsonville Commercial | |
|-------------------------------|-------------------------------|-------------------------------|---------------------------|---------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Shear wall 9/144' | R.C. Shear wall 9/144' | Concrete shear 4/66.4' | Concrete shear 4/66.4' |
| Period (sec.) | 0.8 | 1.0 | 0.3 | 0.4 |
| Soil Conditions | — | — | — | — |
| Earthquake | San Fernando February 9, 1971 | San Fernando February 9, 1971 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 6.5 | 6.5 | 7.0 | 7.0 |
| E. C. D (km) | 30.5 | 30.5 | 13 | 13 |
| Acc. at Base (g's) | 0.20 | 0.18 | 0.28 | 0.39 |
| Acc. at Top (g's) | 0.311 | 0.35 | 0.44 | 1.24 |
| Amplification Factor | 1.55 | 1.94 | 1.57 | 3.18 |

Table A.1. (continued)

| Building Name | Gilroy Historic Commercial | | San Jose Residential | |
|-------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 3/49.6' | Steel Frame 3/49.6' | Concrete shear 10/90' | Concrete shear 10/90'' |
| Period (sec.) | 0.6 | 0.6 | 1.0 | 0.6 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.20 | 0.20 | 0.10 | 0.13 |
| Acc. at Top (g's) | 0.67 | 0.58 | 0.37 | 0.24 |
| Amplification Factor | 3.4 | 2.9 | 3.7 | 1.85 |

Table A.1. (continued)

| Building Name | San Jose Govenrment | | San Jose Commercial | |
|-------------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 13/186.5' | Steel Frame 13/186.5' | R.C. frame 10/124' | R.C. frame 10/124' |
| Period (sec.) | 2.0 | 2.0 | 1.0 | 0.9 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.11 | 0.09 | 0.09 | 0.11 |
| Acc. at Top (g's) | 0.35 | 0.32 | 0.26 | 0.29 |
| Amplification Factor | 3.18 | 3.55 | 2.89 | 2.63 |

Table A.1. (continued)

| Building Name | S. San Francisco Hospital | | San Francisco Comm. Building | |
|-------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 4/52.5' | Steel Frame 4/52.5' | Steel Frame 18/241.4' | Steel Frame 18/241.4' |
| Period (sec.) | 0.6 | 0.6 | 0.9 | 1.1 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.14 | 0.15 | 0.17 | 0.14 |
| Acc. at Top (g's) | 0.57 | 0.61 | 0.23 | 0.20 |
| Amplification Factor | 4.07 | 4.06 | 1.35 | 1.43 |

Table A.1. (continued)

| Building Name | San Bruno Government | | San Bruno Office Building | |
|-------------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Concrete shear 9/104'' | Concrete shear 9/104'' | R.C. frame 6/78' | R.C. frame 6/78' |
| Period (sec.) | 1.1 | 1.0 | 1.0 | 1.1 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.11 | 0.11 | 0.14 | 0.12 |
| Acc. at Top (g's) | 0.23 | 0.32 | 0.25 | 0.32 |
| Amplification Factor | 2.09 | 2.91 | 1.78 | 2.67 |

Table A.1. (continued)

| Building Name | San Francisco Office Building | | Santa Rosa Residential | |
|-------------------------------|-------------------------------|---------------------------|---------------------------|---------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 47/564' | Steel Frame 47/564' | R.C. frame 14/125' | R.C. frame 14/125' |
| Period (sec.) | 1.5 | 1.5 | 1.4 | 1.5 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.13 | 0.26 | 0.04 | 0.05 |
| Acc. at Top (g's) | 0.48 | 0.39 | 0.21 | 0.21 |
| Amplification Factor | 3.7 | 1.5 | 5.25 | 4.2 |

Table A.1. (continued)

| Building Name | Milpitas Industrial Bldg. | | Hayward Office Bldg. | |
|-------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Concrete shear 2/31.5' | Concrete shear 2/31.5' | Concrete shear 6/72' | Concrete shear 6/72' |
| Period (sec.) | 0.33 | 0.2 | 0.7 | 0.8 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.10 | 0.14 | 0.10 | 0.11 |
| Acc. at Top (g's) | 0.14 | 0.58 | 0.24 | 0.34 |
| Amplification Factor | 1.4 | 4.14 | 2.4 | 3.09 |

Table A.1. (continued)

| Building Name | Hayward School Office Bldg. | | Oakland Residential Bldg | |
|-------------------------------|-----------------------------|---------------------------|---------------------------|---------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel R.C. Frame 13/201'' | Steel R.C.Frame 13/201' | Concrete shear 24/219' | Concrete shear 24/219' |
| Period (sec.) | 0.4 | 0.5 | 0.9 | 0.8 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.08 | 0.09 | 0.18 | 0.14 |
| Acc. at Top (g's) | 0.15 | 0.24 | 0.38 | 0.25 |
| Amplification Factor | 1.87 | 2.66 | 2.11 | 1.78 |

Table A.1. (continued)

| Building Name | Okland Office Bldg. | | Berkeley Hospital | |
|-------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Shear wall 2/28' | R.C. Shear wall 2/28' | EB steel frame 2/25.3' | EB steel frame 2/25.3' |
| Period (sec.) | 0.3 | 0.6 | 0.4 | 0.3 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.20 | 0.25 | 0.12 | 0.13 |
| Acc. at Top (g's) | 0.25 | 0.45 | 0.28 | 0.26 |
| Amplification Factor | 1.25 | 1.8 | 2.33 | 2.0 |

Table A.1. (continued)

| Building Name | Richmond Govt. Office | | Walnut Creek Commercial Bld | |
|----------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Frame 3/37.5' | R.C.Frame 3/37.5' | R.C. Frame 10/128.5' | R.C. Frame 10/128.5' |
| Period (sec.) | 0.4 | 0.3 | 0.7 | 0.9 |
| Soil Conditions | —— | —— | —— | —— |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 |
| Magnitude (M_L) | 7.0 | 7.0 | 7.0 | 7.0 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.12 | 0.09 | 0.10 | 0.05 |
| Acc. at Top (g's) | 0.23 | 0.20 | 0.21 | 0.17 |
| Amplification Factor | 1.92 | 2.22 | 2.1 | 3.4 |

Table A.1. (continued)

| Building Name | Pleasant Hill Commercial Bldg. | | Watsonville Tel Building | |
|-------------------------------|--------------------------------|------------------------------|-------------------------------|-------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Concrete shear 3/40.5' | Concrete shear 3/40.5' | R.C Shear wall 4/66.3' | R.C Shear wall 4/66.3' |
| Period (sec.) | 0.3 | 0.6 | 0.4 | 0.4 |
| Soil Conditions | — | — | — | — |
| Earthquake | Loma Prieta Oct. 17, 1989 | Loma Prieta Oct. 17, 1989 | Morgan Hill April 24, 1984 | Morgan Hill April 24, 1984 |
| Magnitude (M_L) | 7.0 | 7.0 | 6.2 | 6.2 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.08 | 0.12 | 0.06 | 0.11 |
| Acc. at Top (g's) | 0.14 | 0.15 | 0.14 | 0.33 |
| Amplification Factor | 1.75 | 1.25 | 2.33 | 3.0 |

| Building Name | Kaiser Medical Center Bldg. | | CSULA Admst. Bldg | |
|-------------------------------|------------------------------|------------------------------|---------------------------|---------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C.Steel Frame 4/52.5' | R.C.Steel Frame 4/52.5' | R.C. shear wall 8/114' | R.C. shear wall 8/114' |
| Period (sec.) | 0.4 | 0.5 | 0.8 | 0.6 |
| Soil Conditions | — | — | — | — |
| Earthquake | Morgan Hill April 24,1984 | Morgan Hill April 24,1984 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 |
| Magnitude (M_L) | 6.2 | 6.2 | 6.1 | 6.1 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.02 | 0.03 | 0.31 | 0.39 |
| Acc. at Top (g's) | 0.11 | 0.17 | 0.48 | 0.27 |
| Amplification Factor | 5.5 | 5.6 | 1.55 | 0.69 |

Table A.1. (continued)

| Building Name | Burbank Federal Savings Bldg. | | Burbank Pacific Manor | |
|-------------------------------|-------------------------------|-------------------------|----------------------------|----------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel frame 6/82.5' | Steel frame 6/82.5' | Concrete shear 10/88.7' | Concrete shear 10/88.7' |
| Period (sec.) | 0.8 | 0.8 | 0.7 | 0.6 |
| Soil Conditions | — | — | — | — |
| Earthquake | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 |
| Magnitude (M_L) | 6.1 | 6.1 | 6.1 | 6.1 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.22 | 0.17 | 0.18 | 0.22 |
| Acc. at Top (g's) | 0.30 | 0.17 | 0.34 | 0.54 |
| Amplification Factor | 1.37 | 1 | 1.89 | 2.45 |

Table A.1. (continued)

| Building Name | N. Holloywood Shearaton Hotel | | CSULB Engr. Bldg | |
|-------------------------------|-------------------------------|----------------------------|-------------------------|-------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Frame 23/177' | Steel R.C.Frame 23/177' | Concrete shear 5/71' | Concrete shear 5/71' |
| Period (sec.) | 0.6 | 0.5 | 0.35 | 0.4 |
| Soil Conditions | — | — | — | — |
| Earthquake | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 |
| Magnitude (M_L) | 6.1 | 6.1 | 6.1 | 6.1 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.11 | 0.09 | 0.1 | 0.1 |
| Acc. at Top (g's) | 0.17 | 0.13 | 0.13 | 0.36 |
| Amplification Factor | 1.54 | 1.44 | 1.3 | 3.6 |

Table A.1. (continued)

| Building Name | Long Beach Harbor Adm. | | UCLA Math Sci. Bldg | |
|----------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | Steel Frame 7/91' | Steel Frame 7/91' | R.C. Frame 7/94.5' | R.C. Frame 7/94.5' |
| Period (sec.) | 1.2 | 1.5 | 0.6 | 0.5 |
| Soil Conditions | — | — | — | — |
| Earthquake | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 |
| Magnitude (M_L) | 6.1 | 6.1 | 6.1 | 6.1 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.05 | 0.07 | 0.05 | 0.04 |
| Acc. at Top (g's) | 0.12 | 0.11 | 0.12 | 0.05 |
| Amplification Factor | 2.4 | 1.57 | 2.4 | 1.2 |

Table A.1. (continued)

| Building Name | Union Bank Building | | Van Nuys Holiday Inn | |
|-------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Frame 13/164' | R.C.Frame 13/164' | R.C. Frame 7/66' | R.C. Frame 7/66' |
| Period (sec.) | — | — | — | — |
| Soil Conditions | — | — | — | — |
| Earthquake | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 | Whittier Oct. 1,1987 |
| Magnitude (M_L) | 6.1 | 6.1 | 6.1 | 6.1 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.18 | 0.11 | 0.16 | 0.16 |
| Acc. at Top (g's) | 0.14 | 0.14 | 0.20 | 0.17 |
| Amplification Factor | 0.77 | 1.27 | 1.26 | 1..06 |

Table A.1. (continued)

| Building Name | 1st Federal Savings Bldg | | Pasadena Office Bldg | |
|-------------------------------|--------------------------|-----------------------|--------------------------------|--------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Frame 2/30' | R.C. Frame 2/30 | Masonry wall 6/82' | Masonry wall 6/82' |
| Period (sec.) | 0.33 | 0.3 | 0.5 | 0.5 |
| Soil Conditions | — | — | — | — |
| Earthquake | Whittier Oct. 1, 1987 | Whittier Oct. 1, 1987 | Sierra Madre, CA June 28, 1991 | Sierra Madre, CA June 28, 1991 |
| Magnitude (M_L) | 6.1 | 6.1 | 5.8 | 5.8 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.05 | 0.05 | 0.20 | 0.14 |
| Acc. at Top (g's) | 0.15 | 0.14 | 0.24 | 0.16 |
| Amplification Factor | 3 | 2.8 | 1.2 | 1.11 |

Table A.1. (continued)

| Building Name | Pasadena Comm. Bldg | | Burbank Residential | |
|-------------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|
| | N-S | E-W | N-S | E-W |
| Configuration (story/ height) | R.C. Frame 9/117' | R.C. Frame 9/117' | R.C. shear wall 10/88' | R.C. shear wall 10/88' |
| Period (sec.) | 1.2 | 1.2 | 0.8 | 0.8 |
| Soil Conditions | — | — | — | — |
| Earthquake | Sierra Madre,CA June 28, 1991 | Sierra Madre,CA June 28, 1991 | Sierra Madre,CA June 28, 1991 | Sierra Madre,CA June 28, 1991 |
| Magnitude (M_L) | 5.8 | 5.8 | 6.6 | 6.6 |
| E. C. D (km) | | | | |
| Acc. at Base (g's) | 0.24 | 0.11 | 0.12 | 0.08 |
| Acc. at Top (g's) | 0.43 | 0.14 | 0.34 | 0.18 |
| Amplification Factor | 1.79 | 1.27 | 2.83 | 2.25 |

NATIONAL CENTER FOR EARTHQUAKE ENGINEERING RESEARCH

LIST OF TECHNICAL REPORTS

The National Center for Earthquake Engineering Research (NCEER) publishes technical reports on a variety of subjects related to earthquake engineering written by authors funded through NCEER. These reports are available from both NCEER's Publications Department and the National Technical Information Service (NTIS). Requests for reports should be directed to the Publications Department, National Center for Earthquake Engineering Research, State University of New York at Buffalo, Red Jacket Quadrangle, Buffalo, New York 14261. Reports can also be requested through NTIS, 5285 Port Royal Road, Springfield, Virginia 22161. NTIS accession numbers are shown in parenthesis, if available.

- NCEER-87-0001 "First-Year Program in Research, Education and Technology Transfer," 3/5/87, (PB88-134275/AS).
- NCEER-87-0002 "Experimental Evaluation of Instantaneous Optimal Algorithms for Structural Control," by R.C. Lin, T.T. Soong and A.M. Reinhorn, 4/20/87, (PB88-134341/AS).
- NCEER-87-0003 "Experimentation Using the Earthquake Simulation Facilities at University at Buffalo," by A.M. Reinhorn and R.L. Ketter, to be published.
- NCEER-87-0004 "The System Characteristics and Performance of a Shaking Table," by J.S. Hwang, K.C. Chang and G.C. Lee, 6/1/87, (PB88-134259/AS). This report is available only through NTIS (see address given above).
- NCEER-87-0005 "A Finite Element Formulation for Nonlinear Viscoplastic Material Using a Q Model," by O. Gyebi and G. Dasgupta, 11/2/87, (PB88-213764/AS).
- NCEER-87-0006 "Symbolic Manipulation Program (SMP) - Algebraic Codes for Two and Three Dimensional Finite Element Formulations," by X. Lee and G. Dasgupta, 11/9/87, (PB88-219522/AS).
- NCEER-87-0007 "Instantaneous Optimal Control Laws for Tall Buildings Under Seismic Excitations," by J.N. Yang, A. Akbarpour and P. Ghaemmaghami, 6/10/87, (PB88-134333/AS).
- NCEER-87-0008 "IDARC: Inelastic Damage Analysis of Reinforced Concrete Frame - Shear-Wall Structures," by Y.J. Park, A.M. Reinhorn and S.K. Kunnath, 7/20/87, (PB88-134325/AS).
- NCEER-87-0009 "Liquefaction Potential for New York State: A Preliminary Report on Sites in Manhattan and Buffalo," by M. Budhu, V. Vijayakumar, R.F. Giese and L. Baumgras, 8/31/87, (PB88-163704/AS). This report is available only through NTIS (see address given above).
- NCEER-87-0010 "Vertical and Torsional Vibration of Foundations in Inhomogeneous Media," by A.S. Veletsos and K.W. Dotson, 6/1/87, (PB88-134291/AS).
- NCEER-87-0011 "Seismic Probabilistic Risk Assessment and Seismic Margins Studies for Nuclear Power Plants," by Howard H.M. Hwang, 6/15/87, (PB88-134267/AS).
- NCEER-87-0012 "Parametric Studies of Frequency Response of Secondary Systems Under Ground-Acceleration Excitations," by Y. Yong and Y.K. Lin, 6/10/87, (PB88-134309/AS).
- NCEER-87-0013 "Frequency Response of Secondary Systems Under Seismic Excitation," by J.A. HoLung, J. Cai and Y.K. Lin, 7/31/87, (PB88-134317/AS).
- NCEER-87-0014 "Modelling Earthquake Ground Motions in Seismically Active Regions Using Parametric Time Series Methods," by G.W. Ellis and A.S. Cakmak, 8/25/87, (PB88-134283/AS).
- NCEER-87-0015 "Detection and Assessment of Seismic Structural Damage," by E. DiPasquale and A.S. Cakmak, 8/25/87, (PB88-163712/AS).

- NCEER-87-0016 "Pipeline Experiment at Parkfield, California," by J. Isenberg and E. Richardson, 9/15/87, (PB88-163720/AS). This report is available only through NTIS (see address given above).
- NCEER-87-0017 "Digital Simulation of Seismic Ground Motion," by M. Shinozuka, G. Deodatis and T. Harada, 8/31/87, (PB88-155197/AS). This report is available only through NTIS (see address given above).
- NCEER-87-0018 "Practical Considerations for Structural Control: System Uncertainty, System Time Delay and Truncation of Small Control Forces," J.N. Yang and A. Akbarpour, 8/10/87, (PB88-163738/AS).
- NCEER-87-0019 "Modal Analysis of Nonclassically Damped Structural Systems Using Canonical Transformation," by J.N. Yang, S. Sarkani and F.X. Long, 9/27/87, (PB88-187851/AS).
- NCEER-87-0020 "A Nonstationary Solution in Random Vibration Theory," by J.R. Red-Horse and P.D. Spanos, 11/3/87, (PB88-163746/AS).
- NCEER-87-0021 "Horizontal Impedances for Radially Inhomogeneous Viscoelastic Soil Layers," by A.S. Veletsos and K.W. Dotson, 10/15/87, (PB88-150859/AS).
- NCEER-87-0022 "Seismic Damage Assessment of Reinforced Concrete Members," by Y.S. Chung, C. Meyer and M. Shinozuka, 10/9/87, (PB88-150867/AS). This report is available only through NTIS (see address given above).
- NCEER-87-0023 "Active Structural Control in Civil Engineering," by T.T. Soong, 11/11/87, (PB88-187778/AS).
- NCEER-87-0024 "Vertical and Torsional Impedances for Radially Inhomogeneous Viscoelastic Soil Layers," by K.W. Dotson and A.S. Veletsos, 12/87, (PB88-187786/AS).
- NCEER-87-0025 "Proceedings from the Symposium on Seismic Hazards, Ground Motions, Soil-Liquefaction and Engineering Practice in Eastern North America," October 20-22, 1987, edited by K.H. Jacob, 12/87, (PB88-188115/AS).
- NCEER-87-0026 "Report on the Whittier-Narrows, California, Earthquake of October 1, 1987," by J. Pantelic and A. Reinhorn, 11/87, (PB88-187752/AS). This report is available only through NTIS (see address given above).
- NCEER-87-0027 "Design of a Modular Program for Transient Nonlinear Analysis of Large 3-D Building Structures," by S. Srivastav and J.F. Abel, 12/30/87, (PB88-187950/AS).
- NCEER-87-0028 "Second-Year Program in Research, Education and Technology Transfer," 3/8/88, (PB88-219480/AS).
- NCEER-88-0001 "Workshop on Seismic Computer Analysis and Design of Buildings With Interactive Graphics," by W. McGuire, J.F. Abel and C.H. Conley, 1/18/88, (PB88-187760/AS).
- NCEER-88-0002 "Optimal Control of Nonlinear Flexible Structures," by J.N. Yang, F.X. Long and D. Wong, 1/22/88, (PB88-213772/AS).
- NCEER-88-0003 "Substructuring Techniques in the Time Domain for Primary-Secondary Structural Systems," by G.D. Manolis and G. Juhn, 2/10/88, (PB88-213780/AS).
- NCEER-88-0004 "Iterative Seismic Analysis of Primary-Secondary Systems," by A. Singhal, L.D. Lutes and P.D. Spanos, 2/23/88, (PB88-213798/AS).
- NCEER-88-0005 "Stochastic Finite Element Expansion for Random Media," by P.D. Spanos and R. Ghanem, 3/14/88, (PB88-213806/AS).

- NCEER-88-0006 "Combining Structural Optimization and Structural Control," by F.Y. Cheng and C.P. Pantelides, 1/10/88, (PB88-213814/AS).
- NCEER-88-0007 "Seismic Performance Assessment of Code-Designed Structures," by H.H-M. Hwang, J-W. Jaw and H-J. Shau, 3/20/88, (PB88-219423/AS).
- NCEER-88-0008 "Reliability Analysis of Code-Designed Structures Under Natural Hazards," by H.H-M. Hwang, H. Ushiba and M. Shinozuka, 2/29/88, (PB88-229471/AS).
- NCEER-88-0009 "Seismic Fragility Analysis of Shear Wall Structures," by J-W Jaw and H.H-M. Hwang, 4/30/88, (PB89-102867/AS).
- NCEER-88-0010 "Base Isolation of a Multi-Story Building Under a Harmonic Ground Motion - A Comparison of Performances of Various Systems," by F-G Fan, G. Ahmadi and I.G. Tadjbakhsh, 5/18/88, (PB89-122238/AS).
- NCEER-88-0011 "Seismic Floor Response Spectra for a Combined System by Green's Functions," by F.M. Lavelle, L.A. Bergman and P.D. Spanos, 5/1/88, (PB89-102875/AS).
- NCEER-88-0012 "A New Solution Technique for Randomly Excited Hysteretic Structures," by G.Q. Cai and Y.K. Lin, 5/16/88, (PB89-102883/AS).
- NCEER-88-0013 "A Study of Radiation Damping and Soil-Structure Interaction Effects in the Centrifuge," by K. Weissman, supervised by J.H. Prevost, 5/24/88, (PB89-144703/AS).
- NCEER-88-0014 "Parameter Identification and Implementation of a Kinematic Plasticity Model for Frictional Soils," by J.H. Prevost and D.V. Griffiths, to be published.
- NCEER-88-0015 "Two- and Three- Dimensional Dynamic Finite Element Analyses of the Long Valley Dam," by D.V. Griffiths and J.H. Prevost, 6/17/88, (PB89-144711/AS).
- NCEER-88-0016 "Damage Assessment of Reinforced Concrete Structures in Eastern United States," by A.M. Reinhorn, M.J. Seidel, S.K. Kunnath and Y.J. Park, 6/15/88, (PB89-122220/AS).
- NCEER-88-0017 "Dynamic Compliance of Vertically Loaded Strip Foundations in Multilayered Viscoelastic Soils," by S. Ahmad and A.S.M. Israil, 6/17/88, (PB89-102891/AS).
- NCEER-88-0018 "An Experimental Study of Seismic Structural Response With Added Viscoelastic Dampers," by R.C. Lin, Z. Liang, T.T. Soong and R.H. Zhang, 6/30/88, (PB89-122212/AS). This report is available only through NTIS (see address given above).
- NCEER-88-0019 "Experimental Investigation of Primary - Secondary System Interaction," by G.D. Manolis, G. Juhn and A.M. Reinhorn, 5/27/88, (PB89-122204/AS).
- NCEER-88-0020 "A Response Spectrum Approach For Analysis of Nonclassically Damped Structures," by J.N. Yang, S. Sarkani and F.X. Long, 4/22/88, (PB89-102909/AS).
- NCEER-88-0021 "Seismic Interaction of Structures and Soils: Stochastic Approach," by A.S. Veletsos and A.M. Prasad, 7/21/88, (PB89-122196/AS).
- NCEER-88-0022 "Identification of the Serviceability Limit State and Detection of Seismic Structural Damage," by E. DiPasquale and A.S. Cakmak, 6/15/88, (PB89-122188/AS). This report is available only through NTIS (see address given above).
- NCEER-88-0023 "Multi-Hazard Risk Analysis: Case of a Simple Offshore Structure," by B.K. Bhartia and E.H. Vanmarcke, 7/21/88, (PB89-145213/AS).

- NCEER-88-0024 "Automated Seismic Design of Reinforced Concrete Buildings," by Y.S. Chung, C. Meyer and M. Shinozuka, 7/5/88, (PB89-122170/AS). This report is available only through NTIS (see address given above).
- NCEER-88-0025 "Experimental Study of Active Control of MDOF Structures Under Seismic Excitations," by L.L. Chung, R.C. Lin, T.T. Soong and A.M. Reinhorn, 7/10/88, (PB89-122600/AS).
- NCEER-88-0026 "Earthquake Simulation Tests of a Low-Rise Metal Structure," by J.S. Hwang, K.C. Chang, G.C. Lee and R.L. Ketter, 8/1/88, (PB89-102917/AS).
- NCEER-88-0027 "Systems Study of Urban Response and Reconstruction Due to Catastrophic Earthquakes," by F. Kozin and H.K. Zhou, 9/22/88, (PB90-162348/AS).
- NCEER-88-0028 "Seismic Fragility Analysis of Plane Frame Structures," by H.H-M. Hwang and Y.K. Low, 7/31/88, (PB89-131445/AS).
- NCEER-88-0029 "Response Analysis of Stochastic Structures," by A. Kardara, C. Bucher and M. Shinozuka, 9/22/88, (PB89-174429/AS).
- NCEER-88-0030 "Nonnormal Accelerations Due to Yielding in a Primary Structure," by D.C.K. Chen and L.D. Lutes, 9/19/88, (PB89-131437/AS).
- NCEER-88-0031 "Design Approaches for Soil-Structure Interaction," by A.S. Veletsos, A.M. Prasad and Y. Tang, 12/30/88, (PB89-174437/AS). This report is available only through NTIS (see address given above).
- NCEER-88-0032 "A Re-evaluation of Design Spectra for Seismic Damage Control," by C.J. Turkstra and A.G. Tallin, 11/7/88, (PB89-145221/AS).
- NCEER-88-0033 "The Behavior and Design of Noncontact Lap Splices Subjected to Repeated Inelastic Tensile Loading," by V.E. Sagan, P. Gergely and R.N. White, 12/8/88, (PB89-163737/AS).
- NCEER-88-0034 "Seismic Response of Pile Foundations," by S.M. Mamoon, P.K. Banerjee and S. Ahmad, 11/1/88, (PB89-145239/AS).
- NCEER-88-0035 "Modeling of R/C Building Structures With Flexible Floor Diaphragms (IDARC2)," by A.M. Reinhorn, S.K. Kunnath and N. Panahshahi, 9/7/88, (PB89-207153/AS).
- NCEER-88-0036 "Solution of the Dam-Reservoir Interaction Problem Using a Combination of FEM, BEM with Particular Integrals, Modal Analysis, and Substructuring," by C-S. Tsai, G.C. Lee and R.L. Ketter, 12/31/88, (PB89-207146/AS).
- NCEER-88-0037 "Optimal Placement of Actuators for Structural Control," by F.Y. Cheng and C.P. Pantelides, 8/15/88, (PB89-162846/AS).
- NCEER-88-0038 "Teflon Bearings in Aseismic Base Isolation: Experimental Studies and Mathematical Modeling," by A. Mokha, M.C. Constantinou and A.M. Reinhorn, 12/5/88, (PB89-218457/AS). This report is available only through NTIS (see address given above).
- NCEER-88-0039 "Seismic Behavior of Flat Slab High-Rise Buildings in the New York City Area," by P. Weidlinger and M. Ettouney, 10/15/88, (PB90-145681/AS).
- NCEER-88-0040 "Evaluation of the Earthquake Resistance of Existing Buildings in New York City," by P. Weidlinger and M. Ettouney, 10/15/88, to be published.
- NCEER-88-0041 "Small-Scale Modeling Techniques for Reinforced Concrete Structures Subjected to Seismic Loads," by W. Kim, A. El-Attar and R.N. White, 11/22/88, (PB89-189625/AS).

- NCEER-88-0042 "Modeling Strong Ground Motion from Multiple Event Earthquakes," by G.W. Ellis and A.S. Cakmak, 10/15/88, (PB89-174445/AS).
- NCEER-88-0043 "Nonstationary Models of Seismic Ground Acceleration," by M. Grigoriu, S.E. Ruiz and E. Rosenblueth, 7/15/88, (PB89-189617/AS).
- NCEER-88-0044 "SARCF User's Guide: Seismic Analysis of Reinforced Concrete Frames," by Y.S. Chung, C. Meyer and M. Shinozuka, 11/9/88, (PB89-174452/AS).
- NCEER-88-0045 "First Expert Panel Meeting on Disaster Research and Planning," edited by J. Pantelic and J. Stoyke, 9/15/88, (PB89-174460/AS).
- NCEER-88-0046 "Preliminary Studies of the Effect of Degrading Infill Walls on the Nonlinear Seismic Response of Steel Frames," by C.Z. Chrysostomou, P. Gergely and J.F. Abel, 12/19/88, (PB89-208383/AS).
- NCEER-88-0047 "Reinforced Concrete Frame Component Testing Facility - Design, Construction, Instrumentation and Operation," by S.P. Pessiki, C. Conley, T. Bond, P. Gergely and R.N. White, 12/16/88, (PB89-174478/AS).
- NCEER-89-0001 "Effects of Protective Cushion and Soil Compliancy on the Response of Equipment Within a Seismically Excited Building," by J.A. HoLung, 2/16/89, (PB89-207179/AS).
- NCEER-89-0002 "Statistical Evaluation of Response Modification Factors for Reinforced Concrete Structures," by H.H-M. Hwang and J-W. Jaw, 2/17/89, (PB89-207187/AS).
- NCEER-89-0003 "Hysteretic Columns Under Random Excitation," by G-Q. Cai and Y.K. Lin, 1/9/89, (PB89-196513/AS).
- NCEER-89-0004 "Experimental Study of 'Elephant Foot Bulge' Instability of Thin-Walled Metal Tanks," by Z-H. Jia and R.L. Ketter, 2/22/89, (PB89-207195/AS).
- NCEER-89-0005 "Experiment on Performance of Buried Pipelines Across San Andreas Fault," by J. Isenberg, E. Richardson and T.D. O'Rourke, 3/10/89, (PB89-218440/AS).
- NCEER-89-0006 "A Knowledge-Based Approach to Structural Design of Earthquake-Resistant Buildings," by M. Subramani, P. Gergely, C.H. Conley, J.F. Abel and A.H. Zaghaw, 1/15/89, (PB89-218465/AS).
- NCEER-89-0007 "Liquefaction Hazards and Their Effects on Buried Pipelines," by T.D. O'Rourke and P.A. Lane, 2/1/89, (PB89-218481).
- NCEER-89-0008 "Fundamentals of System Identification in Structural Dynamics," by H. Imai, C-B. Yun, O. Maruyama and M. Shinozuka, 1/26/89, (PB89-207211/AS).
- NCEER-89-0009 "Effects of the 1985 Michoacan Earthquake on Water Systems and Other Buried Lifelines in Mexico," by A.G. Ayala and M.J. O'Rourke, 3/8/89, (PB89-207229/AS).
- NCEER-89-R010 "NCEER Bibliography of Earthquake Education Materials," by K.E.K. Ross, Second Revision, 9/1/89, (PB90-125352/AS).
- NCEER-89-0011 "Inelastic Three-Dimensional Response Analysis of Reinforced Concrete Building Structures (IDARC-3D), Part I - Modeling," by S.K. Kunnath and A.M. Reinhorn, 4/17/89, (PB90-114612/AS).
- NCEER-89-0012 "Recommended Modifications to ATC-14," by C.D. Poland and J.O. Malley, 4/12/89, (PB90-108648/AS).
- NCEER-89-0013 "Repair and Strengthening of Beam-to-Column Connections Subjected to Earthquake Loading," by M. Corazao and A.J. Durrani, 2/28/89, (PB90-109885/AS).

- NCEER-89-0014 "Program EXKAL2 for Identification of Structural Dynamic Systems," by O. Maruyama, C-B. Yun, M. Hoshiya and M. Shinozuka, 5/19/89, (PB90-109877/AS).
- NCEER-89-0015 "Response of Frames With Bolted Semi-Rigid Connections, Part I - Experimental Study and Analytical Predictions," by P.J. DiCorso, A.M. Reinhorn, J.R. Dickerson, J.B. Radzinski and W.L. Harper, 6/1/89, to be published.
- NCEER-89-0016 "ARMA Monte Carlo Simulation in Probabilistic Structural Analysis," by P.D. Spanos and M.P. Mignolet, 7/10/89, (PB90-109893/AS).
- NCEER-89-P017 "Preliminary Proceedings from the Conference on Disaster Preparedness - The Place of Earthquake Education in Our Schools," Edited by K.E.K. Ross, 6/23/89.
- NCEER-89-0017 "Proceedings from the Conference on Disaster Preparedness - The Place of Earthquake Education in Our Schools," Edited by K.E.K. Ross, 12/31/89, (PB90-207895). This report is available only through NTIS (see address given above).
- NCEER-89-0018 "Multidimensional Models of Hysteretic Material Behavior for Vibration Analysis of Shape Memory Energy Absorbing Devices, by E.J. Graesser and F.A. Cozzarelli, 6/7/89, (PB90-164146/AS).
- NCEER-89-0019 "Nonlinear Dynamic Analysis of Three-Dimensional Base Isolated Structures (3D-BASIS)," by S. Nagarajaiah, A.M. Reinhorn and M.C. Constantinou, 8/3/89, (PB90-161936/AS). This report is available only through NTIS (see address given above).
- NCEER-89-0020 "Structural Control Considering Time-Rate of Control Forces and Control Rate Constraints," by F.Y. Cheng and C.P. Pantelides, 8/3/89, (PB90-120445/AS).
- NCEER-89-0021 "Subsurface Conditions of Memphis and Shelby County," by K.W. Ng, T-S. Chang and H-H.M. Hwang, 7/26/89, (PB90-120437/AS).
- NCEER-89-0022 "Seismic Wave Propagation Effects on Straight Jointed Buried Pipelines," by K. Elhmadi and M.J. O'Rourke, 8/24/89, (PB90-162322/AS).
- NCEER-89-0023 "Workshop on Serviceability Analysis of Water Delivery Systems," edited by M. Grigoriu, 3/6/89, (PB90-127424/AS).
- NCEER-89-0024 "Shaking Table Study of a 1/5 Scale Steel Frame Composed of Tapered Members," by K.C. Chang, J.S. Hwang and G.C. Lee, 9/18/89, (PB90-160169/AS).
- NCEER-89-0025 "DYNA1D: A Computer Program for Nonlinear Seismic Site Response Analysis - Technical Documentation," by Jean H. Prevost, 9/14/89, (PB90-161944/AS). This report is available only through NTIS (see address given above).
- NCEER-89-0026 "1:4 Scale Model Studies of Active Tendon Systems and Active Mass Dampers for Aseismic Protection," by A.M. Reinhorn, T.T. Soong, R.C. Lin, Y.P. Yang, Y. Fukao, H. Abe and M. Nakai, 9/15/89, (PB90-173246/AS).
- NCEER-89-0027 "Scattering of Waves by Inclusions in a Nonhomogeneous Elastic Half Space Solved by Boundary Element Methods," by P.K. Hadley, A. Askar and A.S. Cakmak, 6/15/89, (PB90-145699/AS).
- NCEER-89-0028 "Statistical Evaluation of Deflection Amplification Factors for Reinforced Concrete Structures," by H.H.M. Hwang, J-W. Jaw and A.L. Ch'ng, 8/31/89, (PB90-164633/AS).
- NCEER-89-0029 "Bedrock Accelerations in Memphis Area Due to Large New Madrid Earthquakes," by H.H.M. Hwang, C.H.S. Chen and G. Yu, 11/7/89, (PB90-162330/AS).

- NCEER-89-0030 "Seismic Behavior and Response Sensitivity of Secondary Structural Systems," by Y.Q. Chen and T.T. Soong, 10/23/89, (PB90-164658/AS).
- NCEER-89-0031 "Random Vibration and Reliability Analysis of Primary-Secondary Structural Systems," by Y. Ibrahim, M. Grigoriu and T.T. Soong, 11/10/89, (PB90-161951/AS).
- NCEER-89-0032 "Proceedings from the Second U.S. - Japan Workshop on Liquefaction, Large Ground Deformation and Their Effects on Lifelines, September 26-29, 1989," Edited by T.D. O'Rourke and M. Hamada, 12/1/89, (PB90-209388/AS).
- NCEER-89-0033 "Deterministic Model for Seismic Damage Evaluation of Reinforced Concrete Structures," by J.M. Bracci, A.M. Reinhorn, J.B. Mander and S.K. Kunnath, 9/27/89.
- NCEER-89-0034 "On the Relation Between Local and Global Damage Indices," by E. DiPasquale and A.S. Cakmak, 8/15/89, (PB90-173865).
- NCEER-89-0035 "Cyclic Undrained Behavior of Nonplastic and Low Plasticity Silts," by A.J. Walker and H.E. Stewart, 7/26/89, (PB90-183518/AS).
- NCEER-89-0036 "Liquefaction Potential of Surficial Deposits in the City of Buffalo, New York," by M. Budhu, R. Giese and L. Baumgrass, 1/17/89, (PB90-208455/AS).
- NCEER-89-0037 "A Deterministic Assessment of Effects of Ground Motion Incoherence," by A.S. Veletsos and Y. Tang, 7/15/89, (PB90-164294/AS).
- NCEER-89-0038 "Workshop on Ground Motion Parameters for Seismic Hazard Mapping," July 17-18, 1989, edited by R.V. Whitman, 12/1/89, (PB90-173923/AS).
- NCEER-89-0039 "Seismic Effects on Elevated Transit Lines of the New York City Transit Authority," by C.J. Costantino, C.A. Miller and E. Heymsfield, 12/26/89, (PB90-207887/AS).
- NCEER-89-0040 "Centrifugal Modeling of Dynamic Soil-Structure Interaction," by K. Weissman, Supervised by J.H. Prevost, 5/10/89, (PB90-207879/AS).
- NCEER-89-0041 "Linearized Identification of Buildings With Cores for Seismic Vulnerability Assessment," by I-K. Ho and A.E. Aktan, 11/1/89, (PB90-251943/AS).
- NCEER-90-0001 "Geotechnical and Lifeline Aspects of the October 17, 1989 Loma Prieta Earthquake in San Francisco," by T.D. O'Rourke, H.E. Stewart, F.T. Blackburn and T.S. Dickerman, 1/90, (PB90-208596/AS).
- NCEER-90-0002 "Nonnormal Secondary Response Due to Yielding in a Primary Structure," by D.C.K. Chen and L.D. Lutes, 2/28/90, (PB90-251976/AS).
- NCEER-90-0003 "Earthquake Education Materials for Grades K-12," by K.E.K. Ross, 4/16/90, (PB91-113415/AS).
- NCEER-90-0004 "Catalog of Strong Motion Stations in Eastern North America," by R.W. Busby, 4/3/90, (PB90-251984/AS).
- NCEER-90-0005 "NCEER Strong-Motion Data Base: A User Manual for the GeoBase Release (Version 1.0 for the Sun3)," by P. Friberg and K. Jacob, 3/31/90 (PB90-258062/AS).
- NCEER-90-0006 "Seismic Hazard Along a Crude Oil Pipeline in the Event of an 1811-1812 Type New Madrid Earthquake," by H.H.M. Hwang and C-H.S. Chen, 4/16/90(PB90-258054).
- NCEER-90-0007 "Site-Specific Response Spectra for Memphis Sheahan Pumping Station," by H.H.M. Hwang and C.S. Lee, 5/15/90, (PB91-108811/AS).


- NCEER-90-0008 "Pilot Study on Seismic Vulnerability of Crude Oil Transmission Systems," by T. Ariman, R. Dobry, M. Grigoriu, F. Kozin, M. O'Rourke, T. O'Rourke and M. Shinozuka, 5/25/90, (PB91-108837/AS).
- NCEER-90-0009 "A Program to Generate Site Dependent Time Histories: EQGEN," by G.W. Ellis, M. Srinivasan and A.S. Cakmak, 1/30/90, (PB91-108829/AS).
- NCEER-90-0010 "Active Isolation for Seismic Protection of Operating Rooms," by M.E. Talbott, Supervised by M. Shinozuka, 6/8/9, (PB91-110205/AS).
- NCEER-90-0011 "Program LINEARID for Identification of Linear Structural Dynamic Systems," by C-B. Yun and M. Shinozuka, 6/25/90, (PB91-110312/AS).
- NCEER-90-0012 "Two-Dimensional Two-Phase Elasto-Plastic Seismic Response of Earth Dams," by A.N. Yiagos, Supervised by J.H. Prevost, 6/20/90, (PB91-110197/AS).
- NCEER-90-0013 "Secondary Systems in Base-Isolated Structures: Experimental Investigation, Stochastic Response and Stochastic Sensitivity," by G.D. Manolis, G. Juhn, M.C. Constantinou and A.M. Reinhorn, 7/1/90, (PB91-110320/AS).
- NCEER-90-0014 "Seismic Behavior of Lightly-Reinforced Concrete Column and Beam-Column Joint Details," by S.P. Pessiki, C.H. Conley, P. Gergely and R.N. White, 8/22/90, (PB91-108795/AS).
- NCEER-90-0015 "Two Hybrid Control Systems for Building Structures Under Strong Earthquakes," by J.N. Yang and A. Danielians, 6/29/90, (PB91-125393/AS).
- NCEER-90-0016 "Instantaneous Optimal Control with Acceleration and Velocity Feedback," by J.N. Yang and Z. Li, 6/29/90, (PB91-125401/AS).
- NCEER-90-0017 "Reconnaissance Report on the Northern Iran Earthquake of June 21, 1990," by M. Mehrain, 10/4/90, (PB91-125377/AS).
- NCEER-90-0018 "Evaluation of Liquefaction Potential in Memphis and Shelby County," by T.S. Chang, P.S. Tang, C.S. Lee and H. Hwang, 8/10/90, (PB91-125427/AS).
- NCEER-90-0019 "Experimental and Analytical Study of a Combined Sliding Disc Bearing and Helical Steel Spring Isolation System," by M.C. Constantinou, A.S. Mokha and A.M. Reinhorn, 10/4/90, (PB91-125385/AS).
- NCEER-90-0020 "Experimental Study and Analytical Prediction of Earthquake Response of a Sliding Isolation System with a Spherical Surface," by A.S. Mokha, M.C. Constantinou and A.M. Reinhorn, 10/11/90, (PB91-125419/AS).
- NCEER-90-0021 "Dynamic Interaction Factors for Floating Pile Groups," by G. Gazetas, K. Fan, A. Kaynia and E. Kausel, 9/10/90, (PB91-170381/AS).
- NCEER-90-0022 "Evaluation of Seismic Damage Indices for Reinforced Concrete Structures," by S. Rodriguez-Gomez and A.S. Cakmak, 9/30/90, PB91-171322/AS).
- NCEER-90-0023 "Study of Site Response at a Selected Memphis Site," by H. Desai, S. Ahmad, E.S. Gazetas and M.R. Oh, 10/11/90, (PB91-196857/AS).
- NCEER-90-0024 "A User's Guide to Strongmo: Version 1.0 of NCEER's Strong-Motion Data Access Tool for PCs and Terminals," by P.A. Friberg and C.A.T. Susch, 11/15/90, (PB91-171272/AS).
- NCEER-90-0025 "A Three-Dimensional Analytical Study of Spatial Variability of Seismic Ground Motions," by L-L. Hong and A.H.-S. Ang, 10/30/90, (PB91-170399/AS).

- NCEER-90-0026 "MUMOID User's Guide - A Program for the Identification of Modal Parameters," by S. Rodriguez-Gomez and E. DiPasquale, 9/30/90, (PB91-171298/AS).
- NCEER-90-0027 "SARCF-II User's Guide - Seismic Analysis of Reinforced Concrete Frames," by S. Rodriguez-Gomez, Y.S. Chung and C. Meyer, 9/30/90, (PB91-171280/AS).
- NCEER-90-0028 "Viscous Dampers: Testing, Modeling and Application in Vibration and Seismic Isolation," by N. Makris and M.C. Constantinou, 12/20/90 (PB91-190561/AS).
- NCEER-90-0029 "Soil Effects on Earthquake Ground Motions in the Memphis Area," by H. Hwang, C.S. Lee, K.W. Ng and T.S. Chang, 8/2/90, (PB91-190751/AS).
- NCEER-91-0001 "Proceedings from the Third Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures for Soil Liquefaction, December 17-19, 1990," edited by T.D. O'Rourke and M. Hamada, 2/1/91, (PB91-179259/AS).
- NCEER-91-0002 "Physical Space Solutions of Non-Proportionally Damped Systems," by M. Tong, Z. Liang and G.C. Lee, 1/15/91, (PB91-179242/AS).
- NCEER-91-0003 "Seismic Response of Single Piles and Pile Groups," by K. Fan and G. Gazetas, 1/10/91, (PB92-174994/AS).
- NCEER-91-0004 "Damping of Structures: Part 1 - Theory of Complex Damping," by Z. Liang and G. Lee, 10/10/91, (PB92-197235/AS).
- NCEER-91-0005 "3D-BASIS - Nonlinear Dynamic Analysis of Three Dimensional Base Isolated Structures: Part II," by S. Nagarajaiah, A.M. Reinhorn and M.C. Constantinou, 2/28/91, (PB91-190553/AS).
- NCEER-91-0006 "A Multidimensional Hysteretic Model for Plasticity Deforming Metals in Energy Absorbing Devices," by E.J. Graesser and F.A. Cozzarelli, 4/9/91, (PB92-108364/AS).
- NCEER-91-0007 "A Framework for Customizable Knowledge-Based Expert Systems with an Application to a KBES for Evaluating the Seismic Resistance of Existing Buildings," by E.G. Ibarra-Anaya and S.J. Fenves, 4/9/91, (PB91-210930/AS).
- NCEER-91-0008 "Nonlinear Analysis of Steel Frames with Semi-Rigid Connections Using the Capacity Spectrum Method," by G.G. Deierlein, S-H. Hsieh, Y-J. Shen and J.F. Abel, 7/2/91, (PB92-113828/AS).
- NCEER-91-0009 "Earthquake Education Materials for Grades K-12," by K.E.K. Ross, 4/30/91, (PB91-212142/AS).
- NCEER-91-0010 "Phase Wave Velocities and Displacement Phase Differences in a Harmonically Oscillating Pile," by N. Makris and G. Gazetas, 7/8/91, (PB92-108356/AS).
- NCEER-91-0011 "Dynamic Characteristics of a Full-Size Five-Story Steel Structure and a 2/5 Scale Model," by K.C. Chang, G.C. Yao, G.C. Lee, D.S. Hao and Y.C. Yeh, 7/2/91.
- NCEER-91-0012 "Seismic Response of a 2/5 Scale Steel Structure with Added Viscoelastic Dampers," by K.C. Chang, T.T. Soong, S-T. Oh and M.L. Lai, 5/17/91 (PB92-110816/AS).
- NCEER-91-0013 "Earthquake Response of Retaining Walls; Full-Scale Testing and Computational Modeling," by S. Alampalli and A-W.M. Elgamal, 6/20/91, to be published.
- NCEER-91-0014 "3D-BASIS-M: Nonlinear Dynamic Analysis of Multiple Building Base Isolated Structures," by P.C. Tsopelas, S. Nagarajaiah, M.C. Constantinou and A.M. Reinhorn, 5/28/91, (PB92-113885/AS).

- NCEER-91-0015 "Evaluation of SEAOC Design Requirements for Sliding Isolated Structures," by D. Theodossiou and M.C. Constantinou, 6/10/91, (PB92-114602/AS).
- NCEER-91-0016 "Closed-Loop Modal Testing of a 27-Story Reinforced Concrete Flat Plate-Core Building," by H.R. Somaprasad, T. Toksoy, H. Yoshiyuki and A.E. Aktan, 7/15/91, (PB92-129980/AS).
- NCEER-91-0017 "Shake Table Test of a 1/6 Scale Two-Story Lightly Reinforced Concrete Building," by A.G. El-Attar, R.N. White and P. Gergely, 2/28/91, (PB92-222447/AS).
- NCEER-91-0018 "Shake Table Test of a 1/8 Scale Three-Story Lightly Reinforced Concrete Building," by A.G. El-Attar, R.N. White and P. Gergely, 2/28/91.
- NCEER-91-0019 "Transfer Functions for Rigid Rectangular Foundations," by A.S. Veletsos, A.M. Prasad and W.H. Wu, 7/31/91.
- NCEER-91-0020 "Hybrid Control of Seismic-Excited Nonlinear and Inelastic Structural Systems," by J.N. Yang, Z. Li and A. Danielians, 8/1/91, (PB92-143171/AS).
- NCEER-91-0021 "The NCEER-91 Earthquake Catalog: Improved Intensity-Based Magnitudes and Recurrence Relations for U.S. Earthquakes East of New Madrid," by L. Seeber and J.G. Armbruster, 8/28/91, (PB92-176742/AS).
- NCEER-91-0022 "Proceedings from the Implementation of Earthquake Planning and Education in Schools: The Need for Change - The Roles of the Changemakers," by K.E.K. Ross and F. Winslow, 7/23/91, (PB92-129998/AS).
- NCEER-91-0023 "A Study of Reliability-Based Criteria for Seismic Design of Reinforced Concrete Frame Buildings," by H.H.M. Hwang and H-M. Hsu, 8/10/91, (PB92-140235/AS).
- NCEER-91-0024 "Experimental Verification of a Number of Structural System Identification Algorithms," by R.G. Ghanem, H. Gavin and M. Shinozuka, 9/18/91, (PB92-176577/AS).
- NCEER-91-0025 "Probabilistic Evaluation of Liquefaction Potential," by H.H.M. Hwang and C.S. Lee, 11/25/91, (PB92-143429/AS).
- NCEER-91-0026 "Instantaneous Optimal Control for Linear, Nonlinear and Hysteretic Structures - Stable Controllers," by J.N. Yang and Z. Li, 11/15/91, (PB92-163807/AS).
- NCEER-91-0027 "Experimental and Theoretical Study of a Sliding Isolation System for Bridges," by M.C. Constantinou, A. Kartoun, A.M. Reinhorn and P. Bradford, 11/15/91, (PB92-176973/AS).
- NCEER-92-0001 "Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 1: Japanese Case Studies," Edited by M. Hamada and T. O'Rourke, 2/17/92, (PB92-197243/AS).
- NCEER-92-0002 "Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 2: United States Case Studies," Edited by T. O'Rourke and M. Hamada, 2/17/92, (PB92-197250/AS).
- NCEER-92-0003 "Issues in Earthquake Education," Edited by K. Ross, 2/3/92, (PB92-222389/AS).
- NCEER-92-0004 "Proceedings from the First U.S. - Japan Workshop on Earthquake Protective Systems for Bridges," 2/4/92, to be published.
- NCEER-92-0005 "Seismic Ground Motion from a Haskell-Type Source in a Multiple-Layered Half-Space," A.P. Theoharis, G. Deodatis and M. Shinozuka, 1/2/92, to be published.
- NCEER-92-0006 "Proceedings from the Site Effects Workshop," Edited by R. Whitman, 2/29/92, (PB92-197201/AS).

- NCEER-92-0007 "Engineering Evaluation of Permanent Ground Deformations Due to Seismically-Induced Liquefaction," by M.H. Baziar, R. Dobry and A-W.M. Elgamal, 3/24/92, (PB92-222421/AS).
- NCEER-92-0008 "A Procedure for the Seismic Evaluation of Buildings in the Central and Eastern United States," by C.D. Poland and J.O. Malley, 4/2/92, (PB92-222439/AS).
- NCEER-92-0009 "Experimental and Analytical Study of a Hybrid Isolation System Using Friction Controllable Sliding Bearings," by M.Q. Feng, S. Fujii and M. Shinozuka, 5/15/92.
- NCEER-92-0010 "Seismic Resistance of Slab-Column Connections in Existing Non-Ductile Flat-Plate Buildings," by A.J. Durrani and Y. Du, 5/18/92.
- NCEER-92-0011 "The Hysteretic and Dynamic Behavior of Brick Masonry Walls Upgraded by Ferrocement Coatings Under Cyclic Loading and Strong Simulated Ground Motion," by H. Lee and S.P. Prawel, 5/11/92, to be published.
- NCEER-92-0012 "Study of Wire Rope Systems for Seismic Protection of Equipment in Buildings," by G.F. Demetriades, M.C. Constantinou and A.M. Reinhorn, 5/20/92.
- NCEER-92-0013 "Shape Memory Structural Dampers: Material Properties, Design and Seismic Testing," by P.R. Witting and F.A. Cozzarelli, 5/26/92.
- NCEER-92-0014 "Longitudinal Permanent Ground Deformation Effects on Buried Continuous Pipelines," by M.J. O'Rourke, and C. Nordberg, 6/15/92.
- NCEER-92-0015 "A Simulation Method for Stationary Gaussian Random Functions Based on the Sampling Theorem," by M. Grigoriu and S. Balopoulou, 6/11/92, (PB93-127496/AS).
- NCEER-92-0016 "Gravity-Load-Designed Reinforced Concrete Buildings: Seismic Evaluation of Existing Construction and Detailing Strategies for Improved Seismic Resistance," by G.W. Hoffmann, S.K. Kunnath, J.B. Mander and A.M. Reinhorn, 7/15/92, to be published.
- NCEER-92-0017 "Observations on Water System and Pipeline Performance in the Limón Area of Costa Rica Due to the April 22, 1991 Earthquake," by M. O'Rourke and D. Ballantyne, 6/30/92, (PB93-126811/AS).
- NCEER-92-0018 "Fourth Edition of Earthquake Education Materials for Grades K-12," Edited by K.E.K. Ross, 8/10/92.
- NCEER-92-0019 "Proceedings from the Fourth Japan-U.S. Workshop on Earthquake Resistant Design of Lifeline Facilities and Countermeasures for Soil Liquefaction," Edited by M. Hamada and T.D. O'Rourke, 8/12/92.
- NCEER-92-0020 "Active Bracing System: A Full Scale Implementation of Active Control," by A.M. Reinhorn, T.T. Soong, R.C. Lin, M.A. Riley, Y.P. Wang, S. Aizawa and M. Higashino, 8/14/92, (PB93-127512/AS).
- NCEER-92-0021 "Empirical Analysis of Horizontal Ground Displacement Generated by Liquefaction-Induced Lateral Spreads," by S.F. Bartlett and T.L. Youd, 8/17/92.
- NCEER-92-0022 "IDARC Version 3.0: Inelastic Damage Analysis of Reinforced Concrete Structures," by S.K. Kunnath, A.M. Reinhorn and R.F. Lobo, 8/31/92, to be published.
- NCEER-92-0023 "A Semi-Empirical Analysis of Strong-Motion Peaks in Terms of Seismic Source, Propagation Path and Local Site Conditions, by M. Kamiyama, M.J. O'Rourke and R. Flores-Berrones, 9/9/92.
- NCEER-92-0024 "Seismic Behavior of Reinforced Concrete Frame Structures with Nonductile Details, Part I: Summary of Experimental Findings of Full Scale Beam-Column Joint Tests," by A. Beres, R.N. White and P. Gergely, 9/30/92, to be published.
- NCEER-92-0025 "Experimental Results of Repaired and Retrofitted Beam-Column Joint Tests in Lightly Reinforced Concrete Frame Buildings," by A. Beres, S. El-Borgi, R.N. White and P. Gergely, 10/29/92, to be published.

- NCEER-92-0026 "A Generalization of Optimal Control Theory: Linear and Nonlinear Structures," by J.N. Yang, Z. Li and S. Vongchavalitkul, 11/2/92.
- NCEER-92-0027 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part I - Design and Properties of a One-Third Scale Model Structure," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/1/92, to be published.
- NCEER-92-0028 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part II - Experimental Performance of Subassemblages," by L.E. Aycardi, J.B. Mander and A.M. Reinhorn, 12/1/92, to be published.
- NCEER-92-0029 "Seismic Resistance of Reinforced Concrete Frame Structures Designed Only for Gravity Loads: Part III - Experimental Performance and Analytical Study of a Structural Model," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/1/92, to be published.
- NCEER-92-0030 "Evaluation of Seismic Retrofit of Reinforced Concrete Frame Structures: Part I - Experimental Performance of Retrofitted Subassemblages," by D. Choudhuri, J.B. Mander and A.M. Reinhorn, 12/8/92, to be published.
- NCEER-92-0031 "Evaluation of Seismic Retrofit of Reinforced Concrete Frame Structures: Part II - Experimental Performance and Analytical Study of a Retrofitted Structural Model," by J.M. Bracci, A.M. Reinhorn and J.B. Mander, 12/8/92, to be published.
- NCEER-92-0032 "Experimental and Analytical Investigation of Seismic Response of Structures with Supplemental Fluid Viscous Dampers," by M.C. Constantinou and M.D. Symans, 12/21/92.
- NCEER-92-0033 "Reconnaissance Report on the Cairo, Egypt Earthquake of October 12, 1992," by M. Khater, 12/23/92.
- NCEER-92-0034 "Low-Level Dynamic Characteristics of Four Tall Flat-Plate Buildings in New York City," by H. Gavin, S. Yuan, J. Grossman, E. Pekelis and K. Jacob, 12/28/92.
- NCEER-93-0001 "An Experimental Study on the Seismic Performance of Brick-Infilled Steel Frames," by J.B. Mander, B. Nair, K. Wojkowski and J. Ma, 1/29/93, to be published.
- NCEER-93-0002 "Social Accounting for Disaster Preparedness and Recovery Planning," by S. Cole, E. Pantoja and V. Razak, 2/22/93, to be published.
- NCEER-93-0003 "Assessment of 1991 NEHRP Provisions for Nonstructural Components and Recommended Revisions," by T.T. Soong, G. Chen, Z. Wu, R-H. Zhang and M. Grigoriu, 3/1/93.



Headquartered at the State University of New York at Buffalo

State University of New York at Buffalo
Red Jacket Quadrangle
Buffalo, New York 14261
Telephone: 716/645-3391
FAX: 716/645-3399

ISSN 1088-3800